

GREENSBORO FIRE DEPARTMENT  
FIRE PREVENTION BUREAU  
1514 N. Church Street  
Greensboro, N. C. 27405  
373-2177

To: Chief of Fire Prevention Bureau, City of Greensboro, N. C.

Application is hereby made by the undersigned for a permit to

xx Remove Underground Tank(s)

\_\_\_\_\_ Abandon Underground Tank(s) in or on the premises know as:

EXXON USA, 4701 W. MARKET STREET

(Business Name and Address)

1. Tank

Contractor: Bass Electric Company, P. O. Box 951, Rocky Mount, NC 27801

Contractor's Address: \_\_\_\_\_

Number, size and product type of tanks: (2) 8000 Gal. Gasoline, (1) 6000 Gal. Gasoline

(1) 1000 Gal. Heating Oil, (1) 1000 Gal Waste Oil

2. Permit shall be obtained for the removal or abandonment of underground tanks in place prior to beginning work.
3. Tank contractor shall be licensed as a General Contractor by City Tax Collections.
4. Removal and abandonment of underground tanks in place shall comply with all applicable codes and regulations including the Fire Code, Guilford County Health Regulations, N.F.P.A. 327, and A.P.I. Publication 1604.
5. Notify Fire Prevention at 373-2177 and Guilford County Emergency Services at 373-7565 prior to removal or abandonment in place. Removal or abandonment to be conducted Monday through Friday (no weekends or city holidays) between the hours of 8:00 a.m.-4:00 p.m.).
6. For tank removal or abandonment in place all liquids shall be removed from the tank(s) and properly disposed of in accordance with applicable laws.
7. Prior to removal or abandonment in place tanks shall be purged or rendered inert. Purging or inerting shall be conducted in accordance with applicable standards and regulations. For purging the vapors shall not exceed 20% of the lower flammable limit. For inerting the oxygen content shall be below 8%. Tank contractor shall have the proper operating meters, combustible gas indicator and/or oxygen meter at each job site.

Note: Perchloroethylene will not be allowed as an inerting agent.

8-28-91

8. Tanks which have been removed from the ground shall be promptly removed from the premises to a proper facility. Tanks shall be labeled with legible letters at least 2 inches high similar to the following:

TANK HAS CONTAINED LEADED GASOLINE  
NOT VAPOR FREE  
NOT SUITABLE FOR STORAGE OF FOOD  
OR LIQUIDS INTENDED FOR HUMAN OR ANIMAL CONSUMPTION  
DATE OF REMOVAL: MONTH/DAY/YEAR

9. Tanks to be transported in accordance with all applicable Local, State and Federal regulations. Tank openings to be plugged or capped with one plug having a 1/8 inch vent hole to prevent the tank from being subjected to excessive differential pressure. Tanks to be secured on a truck for transportation to the storage or disposal site with the 1/8 inch vent hole located at the uppermost point on the tank.
10. Tank contractor shall complete and submit the attached Guilford County form upon completion of removal or abandonment of tanks. Information submitted to be accurate and detailed.

I understand and consent to the above stipulated conditions upon which this permit is granted. Failure to obtain permit and comply with regulations may render you liable to the penalties provided by Law.

William K. Bass

W. K. Bass Applicant

Date: 8/28/91

Phone: Day 446-2037 Night \_\_\_\_\_

Capt. J. A. Staley  
Inspector

Date: 8-28-91

Permit Granted  Denied \_\_\_\_\_

cc. Kelly Gage, Guilford County Emergency Services

RAS #43998

4701 W. Market St.

Greensboro, NC

2/04/91

Full Serve Supreme, Self Serve Regular, Supreme meters

Minor seeps with a volume less than one gallon. No further action planned at this location.