

(GW/UST-2)

Site Investigation Report For Permanent Closure or Change-in-Service of U.S.T.

FOR TANKS IN NC

Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (PINK) FOR REGIONAL OFFICE ADDRESS].

N.C. Dept. of Environment and Natural Resources
State Use Only
I.D. Number OCT 25 1993
Date Received

INSTRUCTIONS

Complete and return within (30) days following completion of site investigation.

I. Ownership of Tank(s)

II. Location of Tank(s)

MID-STATE OIL CO.
Owner Name (Corporation, Individual, Public Agency, or Other Entity)
1820 S. MAIN ST.
Street Address
DAVIDSON
City
LEXINGTON NC 27293
County
City Lexington NC 27293
Area Code (704) State 249-0363 Zip Code
Telephone Number

SUMMIT AVE. SUNOCO
Facility Name or Company
Facility ID # (if available)
1103 SUMMIT AVE
Street Address or State Road
(GUILFORD) GREENSBORO 27405
County (919) City Zip Code
Area Code 274-5858 Telephone Number

III. Contact Person

WILLIAM SHIPTON REPAIR MAINT. SUPERVISOR (704) 249-0363
Name Job Title Telephone No. (Area Code)
Closure Contractor JERRY KELLY, INC ELIZABETH CITY, NC (800) 258-4107
Name (Address) Telephone No. (Area Code)
Lab REIC LABORATORY BEAVER, WV (800) 997-8105
Name (Address) Telephone No. (Area Code)

IV. U.S.T. Information

V. Excavation Condition

VI. Additional Information Required

Tank No.	Size in Gallons	Tank Dimensions	Last Contents	Water in Excavation		Free Product		Notable Odor or Visible Soil Contamination	
				Yes	No	Yes	No	Yes	No
1	550	46" x 74"	FUEL OIL		X		X	X	

See reverse side of pink copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

Check the activities completed.

- Contact local fire marshal
 - Notify DEM Regional Office before abandonment
 - Drain & flush piping into tank.
 - Remove all product and residuals from tank
 - Excavate down to tank
 - Clean and inspect tank
 - Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures.
 - Cap or plug all lines except the vent and fill lines.
 - Purge tank of all product & flammable vapors.
 - Cut one or more large holes in the tanks.
 - Backfill the area.
- Date Tank(s) Permanently closed: 4/27/93
Date of Change-in-Service:

- ABANDONMENT IN PLACE**
- Fill tank until material overflows tank opening;
 - Plug or cap all openings;
 - Disconnect and cap or remove vent line
 - Solid inert material used - specify:

- REMOVAL**
- Create vent hole
 - Label tank
 - Dispose of tank in approved manner
- Final tank destination: JERRY KELLY, INC
ELIZABETH CITY, NC

VIII. Certification (Read and Sign)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative

Signature

Date Signed

BILL MULLIGAN - PROJECT MANAGER

Bill Mulligan

10/20/93