



State of North Carolina  
Department of Environment, Health and Natural Resources  
Winston-Salem Regional Office

James G. Martin, Governor  
William W. Cobey, Jr., Secretary

Margaret Plemmons Foster  
Regional Manager

DIVISION OF ENVIRONMENTAL MANAGEMENT  
GROUNDWATER SECTION

July 21, 1992

P & R Trailer Repair  
2229 Bishop Road  
P. O. Box 7450  
Greensboro, NC 27417

Subject: Underground Storage Tank Closure, P & R Trailer Repair,  
2229 Bishop Road, Greensboro, Guilford County

Dear Sir:

On June 23, 1992, we received the soil sample results and closure assessment from the underground storage tank closure at the subject location. As the implementing agency for the Federal Underground Storage Tank Program for the State of North Carolina, we have determined from review of your assessment that the UST system has been closed in accordance with NCAC Title 15A Subchapter 2N Section .0802 and .0803 and 40 CFR 280.71 and 280.72. However, this does not absolve you of any responsibility for contamination that may not have been detected or noted during the site assessment.

If you have any questions, please feel free to contact Kelly Gage at (919) 373-7565.

Sincerely,

A handwritten signature in cursive script that reads "W. Waddell Watters".

W. Waddell Watters  
Hydrogeologist II

WWW/ahl

cc: WSRO  
Central Files - Guilford County  
Guilford County Division of Emergency Services