

Site Investigation Report For Permanent Closure or Change-in-Service of U.S.T.

FOR TANKS IN NC	Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (BLUE) FOR REGIONAL OFFICE ADDRESS].	State Use Only N.C. Dept. NRCO I.D. Number _____ Date Received AUG 28 1991
------------------------	---	--

INSTRUCTIONS

Please complete and return within (30) days following completion of site investigation.

Regional Office

I. Ownership of Tank(s)	II. Location of Tank(s)
Owner Name (Corporation, Individual, Public Agency or Other Entity) HOROW OIL CO. Street Address 4206 UNITED ST City GREENSBORO NC 27407 State NC Zip Code 27407 Area Code 919 Telephone Number 299-0431	Facility Name or Company OUT-AC - DOORS MAN Facility ID # (if available) I-40 & SANDY RIDGE RD. Street Address or State Road GREENSBORO NC 27284 County GREENSBORO NC City GREENSBORO NC Zip Code 27284 Area Code 919 Telephone Number 668-2384

III. Contact Person

Name BUCK HOROW	Job Title PRESIDENT/OWNER	Telephone Number (919) 299-0431
Closure Contractor ARNOLD EQUIP CO	(Address) 205 STACE CORCH TRAIL GREENSBORO NC	
Lab LDW & CO.	(Address) 1711 CATTLE ST. WILMINGTON NC 28402	

IV. U.S.T. Information				V. Excavation Condition				VI. Additional Information Required	
Tank No.	Size in Gallons	Tank Dimensions	Last Contents	Water In Excavation		Free Product		Notable Odor or Visible Soil Contamination	
				Yes	No	Yes	No	Yes	No
	2500	60" x 120"	GASOLINE		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
	* NOTE TANK WAS LARGER THAN INTENT FORM								
	6W/UST-3 FOUND w/ EXCAVATION								
	WAS A 2500 GALLON								

See reverse side of blue copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

Check the activities completed.

- Contact local fire marshal
 - Notify DEM Regional Office before abandonment.
 - Drain & flush piping into tank.
 - Remove all product and residuals from tank
 - Excavate down to tank.
 - Clean and inspect tank.
 - Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures.
 - Cap or plug all lines except the vent and fill lines.
 - Purge tank of all product & flammable vapors.
 - Cut one or more large holes in the tanks.
 - Backfill the area.
- Date Tank(s) Permanently closed: **7-30-91**
 Date of Change-in-Service: _____

- ABANDONMENT IN PLACE**
- Fill tank until material overflows tank opening;
 - Plug or cap all openings;
 - Disconnect and cap or remove vent line
 - Solid inert material used - please specify: _____

- REMOVAL**
- Create vent hole
 - Label tank
 - Dispose of tank in approved manner
- Final tank destination: **Safety Tank**
Disposal

VIII. Certification (Read and Sign)



I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative James R. Brewster Jr. PROJECT MANAGER	Signature JAMES R. BREWSTER JR	Date Signed 8-7-91
---	--	------------------------------

SANDY RIDGE ROAD



E-000 11'0" DEEP FILL
D-010 11'0" DEEP VENT



I-40

OUT OF DOORS MART
GREENSBORO, NC

1/8" = 3'0"

AUG 07 1991

LAW & COMPANY

Consulting and Analytical Chemists

ESTABLISHED 1903

Main Office
1711 Castle Street
P.O. Box 629
Wilmington, N.C. 28402

919-762-7082 919-762-8956
FAX 919-762-8785

REPORT DATE: 8-06-91

ARNOLD EQUIPMENT COMPANY
P.O. BOX 18207
GREENSBORO, N.C. 27419

DATE RECEIVED: 8-01-91
DATE COLLECTED: 7-29-91
COLLECTED BY: CUSTOMER
LAB I.D. # EW 7940

SAMPLE DESCRIPTION: SOIL -"OUT OF DOORS MART" (JOB 214)

TESTS/SAMPLES	UNITS	"D"	"E"
TOTAL PETROLEUM FUEL HYDROCARBON	PPM	<10*	<10*

EPA METHOD # 5030 GAS CHROMATOGRAPH (TPFH)
DETECTION LIMITS - 10 PPM

* BELOW DETECTION LIMITS

Dolly Bidwan
LABORATORY DIRECTOR

