



State of North Carolina
Department of Environment, Health, and Natural Resources
Winston-Salem Regional Office

James G. Martin, Governor
William W. Cobey, Jr., Secretary

Margaret Plemmons Foster
Regional Manager

DIVISION OF ENVIRONMENTAL MANAGEMENT
GROUNDWATER SECTION

October 23, 1990

Howell & Associates
1238 Meadow Avenue
High Point, NC 27260

Dear *Sir*:

This letter is to acknowledge your Notification of Tank Closure as received *October 18, 1990*.

The results of the required assessment (40 CFR, Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 40 CFR 280.71. Any violations will be submitted to EPA with a request for enforcement. Enclosed is an attachment that is to be used for the information required for closure assessment.

You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

Thomas A. Salley

Thomas A. Salley
Hydrogeological Technician

TAS/ahl
Enclosure
cc: WSRO

ENSCC Corp.