



GUILFORD COUNTY DEPARTMENT OF PUBLIC HEALTH
DIVISION OF ENVIRONMENTAL HEALTH

301 N. Eugene Street
P.O. Box 3508
Greensboro: NC 27401
Phone: (919) 373-3771

UNDERGROUND TANK REMOVED OR ABANDONED IN PLACE

TO BE TYPED OR PRINTED--

Owner's Name: Howell and Associates

Address: 1238 MontLiew Avenue; HighPoint, NC 27260

Telephone: (919) 887-1050

Property Address: 2001 Brentwood Street; High Point, NC
(if different from above)

Date removal or abandonment: November 9, 1990

Contractor's Name: ENSCI Corporation

Address: 1108 Old Thomasville Rd.; High Point, NC 27260

Telephone: (919) 883-7505

Final disposition of removed product: Tank empty prior to removal

Evidence of leakage? Yes No Date noticed: After excavation and removal of tank

Soil samples taken? Yes No If yes, results must be forwarded to Health Department

Material used to fill tank: N/A

Tank size: 1,000 gallons

Final disposition of tank, if removed: Safeway Tank Disposal

Final disposition of contaminated soil, if removed: Approximately 8 cu. yds. were removed and spread out onsite (approx. 2"). Area was then fertilized and seeded.

Remarks:

Henry M. Lawrence
Signature

11-27-90
Date

White—Health Dept.
Yellow—Fire Dept.
Pink—Owner

LAW & COMPANY
Consulting and Analytical Chemists

ESTABLISHED 1903

Main Office
1711 Castle Street
P.O. Box 629
Wilmington, N.C. 28402

919-762-7082 919-762-8956
FAX 919-762-8785

REPORT DATE: 11-14-90

ENSCI CORPORATION
1108 OLD THOMASVILLE ROAD
HIGH POINT, N.C. 27260

DATE RECEIVED: 11-14-90
DATE COLLECTED: 11-09-90
COLLECTED BY: CUSTOMER
LAB I.D. # EW 4032

SAMPLE DESCRIPTION: SOIL WAYSIDE INTERIORS

<u>TESTS/SAMPLES</u>	<u>UNITS</u>	<u>W.I. 1</u>	<u>W.I. 2</u>
TOTAL PETROLEUM FUEL HYDROCARBON	PPM	<10*	<10*
TOTAL PETROLEUM HYDROCARBON	PPM	<10*	<10*

EPA METHOD # 5030 GAS CHROMATOGRAPH (TPFH)
EPA MEHTOD # 3550 GAS CHROMATOGRAPH (TPH)

DETECTION LIMITS = 10 PPM

* BELOW DETECTION LIMITS.

Holly Bickman
LABORATORY DIRECTOR

