


Oak Hollow  
1313 Oakview Road  
High Point, N.C. 27265



Gentlemen:

This report is to advise that Mickey's Backhoe Service has completed the tank removal at the subject location.. The following information is for your files.

Form GW/UST-3 "Notice of Intent to Permanently Close Underground Storage Tank," was submitted to your office on December 5, 1990. Removal date was originally scheduled for A.S.A.P.

Residual Product and/or water was removed and disposed of by tank owner, prior to excavation.

The subject tank was excavated and removed on April 2, 1991. The tank was transported by the City of High Point to Safe-way Tank Disposal. The tank was found to be in good condition. The removal fuel oil tank was 64" in diameter x 12' long and had a nominal capacity of 2,000 gallons.

Neither ground water nor free product were found in the excavation. Soil samples were collected in brass cylinders provided by Guilford Laboratories at an approximate depth of 18" to 20" below bottom of tank.

Soil samples were collected by Jack Cox of the City of High Point, preserved ice, refrigerated and delivered to Guilford Laboratories for total Petroleum Hydrocarbon. Analysis by EPA method 3500 and EPA method 5030 on April 4, 1991.

Results are as follows:

Sample No. East - Filled - 18" to 20" below tank, <10 ppm. by EPA method 3500 and EPA , method 5030.

Sample No. West - Vent end - 18" to 20" below tank, <10 ppm by EPA method 3500 and EPA method 5030.

The pit excavation has been backfilled with clean sand rock. The location is served by city water and sewer service, no public or private wells are on the property, and the site does not have surface water on or adjacent to or in the vicinity of the property.

I hope you have found the above information satisfactory to complete the subject tank closure. If I can be of further assistance, please call me at (919) 475-7282.

Respectfully submitted,

A handwritten signature in cursive script, appearing to read "Mickey James".

It is the intent of the tank(s) owner, to Permanently Close the tank(s) listed below in the manner indicated.  
 All tanks will be empty and clean, free of all liquids and sludges as required in 40 CFR, Part 280.71 (b).

## NOTIFICATION OF TANK CLOSURE

OWNERSHIP OF TANK(S)	LOCATION OF TANK(S)
Name: <u>HP Parkers Recreation</u>	Site Name: <u>Out Hollow Maint Complex</u>
Address: <u>221 Nathan Hunt Dr</u> <u>High Point NC 27260</u>	Address: <u>1313 Oakview Rd</u> <u>High Point NC</u>
Phone Number: _____	County: <u>Guilford</u>

TANKS FOR CLOSURE			
TANK NUMBER	TANK CAPACITY	LAST CONTENTS	CLOSURE METHOD
Tank 1	<u>1000</u>	<u>Fuel Oil</u>	<u>To Be Removed</u> <del>To Be Filled</del> To Be Removed
Tank 2	_____	_____	<del>To Be Filled</del> To Be Removed
Tank 3	_____	_____	<del>To Be Filled</del> To Be Removed
Tank 4	_____	_____	<del>To Be Filled</del> To Be Removed
Tank 5	_____	_____	<del>To Be Filled</del> To Be Removed

TANK(S) CLOSURE OPERATIONS TO BE PERFORMED BY:	
<b>MICKEY'S BACKHOE SERVICE</b>	
(Contractor) Name: <u>Mickey F. Jones</u>	
Address: <u>200 County Line Rd.</u> <u>Thomasville, N.C. 27360</u>	
Contact: _____	Phone: <u>(919) 475-7282</u>
<input checked="" type="checkbox"/> Is this operator knowledgeable of the requirements for the removal/filling of underground storage tanks ? <input checked="" type="checkbox"/> Is this operator and employees medically monitored as required by OSHA 29 CFR, Part 1910.120 (f) ? <input checked="" type="checkbox"/> Is this operator and employees specifically trained as required by OSHA 29 CFR, Part 1910.120 (e) ?	

TANK(S) CLOSURE ASSESSMENT TO BE PERFORMED BY:	
<b>MICKEY'S BACKHOE SERVICE</b>	
(Contractor) Name: <u>Mickey F. Jones</u>	
Address: <u>200 County Line Rd.</u> <u>Thomasville, N.C. 27360</u>	
Contact: _____	Phone: <u>(919) 475-7282</u>
<input checked="" type="checkbox"/> Is this operator knowledgeable of the requirements for the closure assessment in 40 CFR, Part 280.72 ? <input checked="" type="checkbox"/> Is this operator and employees medically monitored as required by OSHA 29 CFR, Part 1910.120 (f) ? <input checked="" type="checkbox"/> Is this operator and employees specifically trained as required by OSHA 29 CFR, Part 1910.120 (e) ?	

NOTIFICATION SUBMITTAL / NOTIFICATION DATE	
<b>MICKEY'S BACKHOE SERVICE</b>	
Name: <u>Mickey F. Jones</u>	Scheduled Removal Date: <u>ASAP</u>
Signature: <u>Mickey Jones</u>	Date Submitted: <u>12-5-90</u>

Tank owners are required to notify the implementing state agency at least 30 days before a Permanent Tank Closure as required in 40 CFR, Part 280.71 (a). For further information contact the U. S. Environmental Protection Agency RCRA / Superfund Hotline at 800-424-9346

GUILFORD LABORATORIES  
Chain Of Custody Form

Matrix Codes:

- S = Soil
- WM = Waste Water
- DM = Drink Water
- GM = Ground Water
- 0 = Other

Sampler's Name : City of Hgbr  
 Sampling Date : 1/17/91 (p / a)  
 Sampling Time : 8:45 (p / a)

Sampling Site : 600 West St  
1212 Cassell St  
1212 Oak St  
602 West Main St - Jerusalem

Sample Description

High site

Matrix Container

Preservation

Analysis

fuel oil

Relinquished by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Received by : O. Pradsky Date: 1/17/91 Time 8:45 (p / a)

Relinquished by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Received by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Relinquished by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Received by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Relinquished by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Received by : \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_ Time \_\_\_:\_\_\_:\_\_\_ (p / a)

Guilford Labs Phone : 919-854-2320

RECEIVING REPORT

From:

City of Highpoint  
Po 230  
Highpoint 27261  
Parks & Rec.  
P.O. # B 63152

Received by:

CW Butler

SAFEWAY TANK DISPOSAL, INC.

Transported by:

City of Highpoint

Tank Disposal Number	Size	Weight	Product	Date Received	Origin
4164	1000		Fuel oil	4-2-91	600 Jail St Hillside Park H.P.
4165	550		Fuel oil	4-2-91	1210 Cassel St Goldston Park H.P.
4166	2000		Fuel oil	4-2-91	1313 cKevind Rd <del>OK</del> Hollow Park H.P.
4171	1000		Fuel oil	4-3-91	602 West Main St City Lake Park H.P.

Safeway Tank Disposal, Inc. accepts the liability for the tank(s) and contents on this report. The tank(s) and contents must be a petroleum product. If at any time the tanks are found to contain any product other than a petroleum product SAFEWAY TANK DISPOSAL, INC. has the right to refuse disposal or negotiate a price for disposal. Customer will be liable for any clean-up or other cost resulting from contamination by a substance other than a petroleum product.

Safeway Tank Disposal, Inc. agrees to dispose of petroleum tanks and contents in accordance with local, state, and federal regulation. Certificate of Disposal to follow.

CW Butler

SAFEWAY TANK DISPOSAL, INC.



**GUILFORD LABORATORIES, INC.**  
P.O. Box 9735/Plaza Station/Greensboro, N.C. 27408

April 15, 1991

REPORT OF ANALYSIS


JOB #: COH10404  
CUSTOMER: City of High Point                      ATTN: Jack Cox  
SITE: 1313 Oakview Road  
SAMPLE: # 1849 1000 GAL FUEL OIL EAST  
          # 1850 1000 GAL FUEL OIL WEST

<u>RESULTS</u>		<u>1849</u>	<u>1850</u>
Total Petroleum Hydrocarbons by EPA Method 3500	(ppm)	<10	<10
Total Petroleum Hydrocarbons as Gasoline by EPA Method 5030	(ppm)	<10	<10

Guilford Laboratories, Inc.

  
J. A. Rayburn

OAKVIEW Rd.




TANK # 1 - Fuel Oil



SAMPLE # EAST  
FILL END

SAMPLE # WEST  
VENT END



**DAK HOLLOW  
MAINT. Complex**

**OAK  
HOLLOW  
LAKE**

311

68

ALT 70

68

CORPORATE

CORPORATE

PROPOSED HIGH/POINT ARCHDALE BYPASS

PROPOSED  
DIATE LOOP

EAST LEXINGTON AVE.

EASTCHESTER DR.

WORTLED AVE.

AVE.

WOODWAY DR.