N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

UNDERGROUND STORAGE TANK(S)

SITE NAME: Northeast Fire Dept. #32

REGULATED ✓ NONREGULATED ____

	YES	NO
RELEASE CONFIRMED:		✓
CLEAN-UP INITIATED:		
TANK(S) REMOVED:	✓	
RELEASE UNDER CONTROL:		
CLEAN-UP COMPLETED:		

TECHNICIAN: Sharon K. Chab

DATE: 3 / 1 / 94

COMMENTS:

Northeast Fire Dept. #32

✓ USGS MAP — 1-3-94 2N NOV for failure to submit closure report

✓ BASE MAP NOT TO SCALE — 1-13-94 received closure report; 1-21-94 Inadequate letter - due 2-4-94

✓ ORIENTATION OF UST

✓ LENGTH OF UST — fill lines were 30" long (so 30" to top of tanks)

✓ DIAMETER OF UST

✓ VOLUME OF UST — 1,000 gasoline CLEAN; 550 diesel

✓ MATERIAL STORED — <10 ppm (LUFT ?)

✓ SAMPLE LOCATIONS — <10 ppm 5030; <10 ppm 5030

✓ DEPTH OF SAMPLE

✓ SIDE OR FLOOR SAMPLE

✓ DEPTH OF TANK BURIAL

✓ HOW SAMPLE WAS COLLECTED

✓ SAMPLES PRESERVED AND TRANSPORTED

NA TOOLS DECONTAMINATED

✓ TIME/DATE SAMPLE COLLECTED

✓ TIME/DATE LAB RECEIVED

✓ LAB RESULTS

✓ ANALYSIS METHOD

✓ C.O.C.

✓ REFERENCE TO SAMPLING POINT ON MAP

✓ CORRECT # OF SAMPLES

✓ WITHIN 14 DAYS HOLDING TIME FOR SAMPLES

✓ TANK AND CONTENTS DESTINATION — given to farmer Brown to haul water? water for what? animal consumption?

NA DISPOSITION OF SOIL

✓ REMOVAL DATE 8-20-93

✓ COMPLETE GW/UST-2 FORM

1-20-94 Mike Vaughn (Water Tech. Controls) informed me that Jim Meyers from DEM said they could use liquid extraction instead of the sonication extraction method for the diesel fraction of TPH analysis.

1-20-94 Joe Nimozura - not there

2-9-94 656-3652 Monticello Oil - secretary thought info. was sent. Thomas Andrews will be gone for a couple of weeks.

3-1-94 Thomas Andrews - Does farmer Brown know he can't use the tanks to hold water for human or animal consumption?

YES. He uses it to plant tobacco (water it in)