

GUILFORD COUNTY DEPARTMENT OF EMERGENCY SERVICES
FIRE SERVICE DIVISION
P. O. Box 18807
Greensboro, N. C. 27419

TO: Chief Fire Inspector

Application is hereby made by the undersigned for a permit to

X Remove Underground Tank(s)

Abandon Underground Tank(s) in or on the premises
known as:

Wynnefield Properties, INC
5614 Riverdale Dr.
Jamestown, NC
27282
(Business Name and Address)

1. Tank Contractor: Glover Grading

Contractor's Address: 430 N. Scientific St.
High Point, NC 27260

Number, Size and Product of Tank(s) 1 - 8,000 - gasoline
(unleaded)

2. Permit shall be obtained for removal or abandonment of underground tanks in place prior to beginning work.
3. Removal and abandonment of underground tanks in place shall comply with all applicable codes and regulation including the fire code, N.F.P.A 327, and A.P.I. Publication 1604.
4. Notify Fire Service Division at 373-7565 and Toxic Hazards Division, at 373-7565, minimum one working day prior to removal or abandonment in place.
5. For tank removal or abandonment in place all liquids shall be removed from the tank(s) and properly disposed of in accordance with applicable laws.
6. Prior to removal or abandonment in place tanks shall be purged or rendered inert. Purging or inerting shall be conducted in accordance with applicable standards and regulations. For purging the vapors shall not exceed 20% of the lower flammable limits. For inerting the oxygen content shall be below 8%. Tank contractors shall have the proper operating meters, combustible gas indicator and/or oxygen meter at each job site.

7. Tanks which have been removed from the ground shall be properly removed from the premises to a proper facility. Tanks shall be labeled with legible letters at least two (2) inches high, similar to the following:

TANK HAS CONTAINED LEADED GASOLINE
NOT VAPOR FREE
NOT SUITABLE FOR STORAGE OF FOOD OR LIQUID
INTENDED FOR HUMAN OR ANIMAL CONSUMPTION
DATE OF REMOVAL : MONTH/DAY/YEAR
PERMIT #

8. Tanks to be transported in accordance with all applicable local, state and federal regulations. Tank openings to be plugged or capped with one plug having a 1/8" inch vent hole to prevent the tank from being subjected to excessive differential pressure. Tanks to be secured on a truck or trailer for transportation to the storage or disposal site with the 1/8" inch vent hole located at the uppermost point on the tank.

9. Tank contractor shall complete and submit Guilford County Health Department form upon completion of removal or abandonment of tanks. Information submitted to be accurate and detailed. Health and Fire Copy mailed to Guilford County Emergency Services.

I understand and consent to the above stipulated conditions upon which this permit is granted. Failure to obtain permit and comply with regulation may render you liable to the penalties provided by law.

James C. Buford
Applicant

Joseph W. Ryzard
Fire Inspector

Date : 12-6-93

12-6-93

Phone : 910-454-6134
Day

Permit #: 902.5-098

910-841-8159
Night

Granted: Denied

11:00 A.M. 12-7-93

PAGE 3

ADDITIONS:

1. Result of soil sample shall be sent to this office.
2. Please call this office the day before you plan to remove the tank.