



RECEIVED  
N.C. Dept. NRCD

JAN 30 1990



G & H OIL EQUIPMENT, INC.

Winston-Salem  
Regional Office

January 26, 1990

NC Department of Natural Resources  
and Community Development  
Division of Environmental Management  
Groundwater Section  
8025 North Point Blvd., Suite 100  
Winston Salem, NC 27106-3295

Subject: Tank Closure  
New Home Building Supply  
625 S. Mendenhall Street  
Greensboro, NC

Gentlemen:

On December 22, 1989, G & H removed one (1) 1,000-gallon gasoline storage tank at the subject location.

All product and/or water was removed and disposed of by owner, Kyle's Friendly Service, prior to excavation.

The excavated tank was found in good condition and site contamination was not suspected. The tank was delivered to Safeway Tank Disposal, Inc., for certified disposal.

One (1) soil sample was taken from two (2) feet below tank bottom and delivered to Guilford Laboratories for Total Petroleum Hydrocarbon Analysis. Copy attached. Results were as follows:

Sample #5252: by SW-846, method 5030 84 ppm

The tank excavation was backfilled with existing soil and other clean fill material to grade.

Please call me at 1-800-632-0415 if you have any questions.

Sincerely yours,

*William V. Hill*  
William V. Hill  
Vice President

Attachments

Copy to: Kyle H. Harris, Kyle's Friendly Service  
Vic Dasso, New Home Building Supply





**GUILFORD LABORATORIES, INC.**  
P.O. Box 9735/Plaza Station/Greensboro, N.C. 27408

January 10, 1990

REPORT OF ANALYSIS

JOB #: GH91227

CUSTOMER: G & H Oil Equipment, Inc.

SAMPLES: #5252 Soil New Home Builders


RESULTS:

#5252

Tot. Petroleum Hydrocarbons  
as Gasoline by SW-846  
Method 5030

84

GUILFORD LABORATORIES, INC.

  
J. A. Rayburn