



RECEIVED  
N.C. Dept. NRCD

FEB 2 1990



Winston-Salem  
Regional Office

G & H OIL EQUIPMENT, INC.

February 1, 1990

Mr. Tom Sally  
NC Department of Natural Resources  
and Community Development  
Division of Environmental Management  
Groundwater Section  
8025 North Point Blvd., Suite 100  
Winston Salem, NC 27106-3295

Subject: Tank Closure -  
New Home Building Supply  
1715 Spring Garden Street  
Greensboro, NC

Dear Mr. Sally:

In response to your telephone request January 26, 1990, to identify method used in soil analysis at subject location, I requested a statement from Guilford Laboratories with this information.

Attached is a revised copy of their October 16, 1989, Report of Analysis, Samples No. 4223 and 4224, which indicates EPA method 3550 was used to obtain test results.

Please call me if additional information is needed.

Sincerely yours,

William V. Hill  
Vice President

Attachment: Revised Report

Copy to: New Home Building Supply



**GUILFORD LABORATORIES, INC.**  
P.O. Box 9735/Plaza Station/Greensboro, N.C. 27408

October 16, 1989

REPORT OF ANALYSIS

JOB #: GH90928

CUSTOMER: G & H Oil Equipment Inc                      ATTN: Bill Hill

SAMPLE:            # 4223 NEW HOME BUILDERS FILL SAMPLE  
                      # 4224 NEW HOME BUILDERS SAMPLE #2

<u>RESULTS</u>	<u>4223</u>	<u>4224</u>
Total Petroleum Hydrocarbons (ppm) by EPA Method 3550	<15	<14

Guilford Laboratories, Inc.

*J. A. Rayburn*  
J. A. Rayburn