



State of North Carolina
Department of Natural Resources and Community Development
Winston-Salem Regional Office

James C. Martin, Governor

William W. Cobey, Jr., Secretary

DIVISION OF ENVIRONMENTAL MANAGEMENT
GROUNDWATER SECTION

July 12, 1990

U.S. Navy
1838 J. McCloud Rd.
Greensboro, NC 27409

Dear Sir:

This letter is to acknowledge your Notification of Tank Closure as received July 6, 1990.

The results of the required assessment (40 CFR, Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 40 CFR 280.71. Any violations will be submitted to EPA with a request for enforcement. Enclosed is an attachment that is to be used for the information required for closure assessment.

You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

Andrew M. Raring
Andrew M. Raring
Hydrogeological Regional
Supervisor

AMR/ahl
Enclosure

cc: WSRO
GEO Services

8025 North Point Boulevard, Suite 100, Winston-Salem, N.C. 27106-3295 • Telephone 919-761-2351

It is the intent of the tank(s) owner, to Permanently Close the tank(s) listed below in the manner indicated. ✓
 All tanks will be empty and clean, free of all liquids and sludges as required in 40 CFR, Part 280.71 [b].

NOTIFICATION OF TANK CLOSURE

RECEIVED
N.C. Dept. NRCO

JUL 6 1990

OWNERSHIP OF TANK(S)	LOCATION OF TANK(S)
Name: <u>U.S. NAVY</u>	Winston-Salem Regional Office <i>(Naval Reserve Center)</i>
Address: <u>7838 MC CLOUD RD</u> <u>GREENSBORO NC 27409-9634</u>	Site Name: <u>NAVAL & MARINE CORPS RESV CTR</u> Address: <u>MC CLOUD RD # 7838</u> <u>GREENSBORO NC</u>
Phone Number: <u>(919) 668 0053</u>	County: _____

TANKS FOR CLOSURE			
TANK NUMBER	TANK CAPACITY	LAST CONTENTS	CLOSURE METHOD
Tank 1	<u>5,000 Gal.</u>	<u>Unleaded Gasoline</u>	To Be Removed ✓ To Be Filled
Tank 2	<u>5,000 Gal.</u>	<u>NEVER USED</u>	To Be Removed ✓ To Be Filled
Tank 3	_____	_____	To Be Removed To Be Filled
Tank 4	_____	_____	To Be Removed To Be Filled
Tank 5	_____	_____	To Be Removed To Be Filled

TANK(S) CLOSURE OPERATIONS TO BE PERFORMED BY:	
(Contractor) Name: <u>GEO Services</u>	
Address: <u>P.O. Box 444</u> <u>Hixson</u> State <u>TN</u> Zip <u>37343</u>	
Contact: <u>Kris Bancroft</u> <u>RPG PE</u> Phone: <u>(615) 877 8301</u>	
<u>Yes</u> Is this operator knowledgeable of the requirements for the removal/filling of underground storage tanks ?	
<u>Yes</u> Is this operator and employees medically monitored as required by OSHA 29 CFR, Part 1910.120 [f] ?	
<u>Yes</u> Is this operator and employees specifically trained as required by OSHA 29 CFR, Part 1910.120 [e] ?	

TANK(S) CLOSURE ASSESSMENT TO BE PERFORMED BY:	
(Contractor) Name: <u>GEO Services</u>	
Address: <u>P.O. Box 444</u> <u>Hixson</u> State <u>TN</u> Zip <u>37343</u>	
Contact: _____ Phone: _____	
<u>Yes</u> Is this operator knowledgeable of requirements for the closure assessment in 40 CFR, Part 280.72 ?	
<u>Yes</u> Is this operator and employees medically monitored as required by OSHA 29 CFR, Part 1910.120 [f] ?	
<u>Yes</u> Is this operator and employees specifically trained as required by OSHA 29 CFR, Part 1910.120 [e] ?	

NOTIFICATION SUBMITTAL / NOTIFICATION DATE	
Name: <u>Kris Bancroft</u>	Scheduled Removal Date: <u>8/15 & 16/90</u>
Signature: <u>Kris Bancroft</u>	Date Submitted: <u>7/3/90</u>

Tank owners are required to notify the implementing state agency at least 30 days before a Permanent Tank Closure as required in 40 CFR, Part 280.71 [a]. For further information contact the U. S. Environmental Protection Agency RCRA / Superfund Hotline at 800-424-9346