



State of North Carolina
 Department of Natural Resources and Community Development
 Winston-Salem Regional Office

James G. Martin, Governor

William W. Cobey, Jr. Secretary

DIVISION OF ENVIRONMENTAL MANAGEMENT
 GROUNDWATER SECTION

Jan 30, 1990

National Freight
505 Chimney Rock Rd.
Greensboro, NC 27410

Dear Sir:

This letter is to acknowledge your Notification of Tank Closure as received Jan 26, 1990.

The results of the required assessment (40 CFR, Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 40 CFR 280.71. Any violations will be submitted to EPA with a request for enforcement. Enclosed is an attachment that is to be used for the information required for closure assessment.

You may contact Larry Lucas, Stephen Williams or me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

Steve A. Kay

Steve A. Kay
 Hydrogeological Technician

SAK/ahl
 Enclosure
 cc: WSRO

City/County Inspections Division
Piedmont Env. Services, Inc