

FOR TANKS IN NC

Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (PINK) FOR REGIONAL OFFICE ADDRESS].

State Use Only I.D. Number MAY 21 1993 Date Received Winston-Salem

INSTRUCTIONS

Complete and return within (30) days following completion of site investigation.

I. Ownership of Tank(s)

II. Location of Tank(s)

MONTGOMERY WARD & CO., INC
Owner Name (Corporation, Individual, Public Agency, or Other Entity)
140 CLEARWATER MALL
Street Address
County CLEARWATER, FL 34624
City State Zip Code 813-795-8950
Area Code Telephone Number

MONTGOMERY WARD AUTO CENTER
Facility Name or Company
0-010910
Facility ID # (if available)
100 CAROLINA CIRCLE MALL
Street Address or State Road
GUILFORD GREENSBORO 27405
County City Zip Code
919-375-4000
Area Code Telephone Number

III. Contact Person

BOB SOLOMON STORE MANAGER 919-375-4000
Name Job Title Telephone No. (Area Code)
Closure Contractor REICH GRADING 540 LESLIE DRIVE, WINSTON-SALEM, NC 919-377-9339
(Name) (Address) Telephone No. (Area Code)
Lab LAW ENVIRONMENTAL LABS (Address) KENNESAW, GA 404-421-3000
(Name) (Address) Telephone No. (Area Code)

IV. U.S.T. Information

V. Excavation Condition

VI. Additional Information Required

Table with columns: Tank No., Size in Gallons, Tank Dimensions, Last Contents, Water In Excavation (Yes/No), Free Product (Yes/No), Notable Color or Visible Soil Contamination (Yes/No). Row 1: 1, 2000, 5'x5'x5', OIL, No, Yes, No, Yes.

See reverse side of pink copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

Check the activities completed.

- Checklist items: Contact local fire marshal, Notify DEM Regional Office before abandonment, Drain & flush piping into tank, Remove all product and residuals from tank, Excavate down to tank, Clean and inspect tank, Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures, Cap or plug all lines except the vent and fill lines, Purge tank of all product & flammable vapors, Cut one or more large holes in the tanks, Backfill the area. Date Tank(s) Permanently closed: 3/25/93 Date of Change-in-Service:

- ABANDONMENT IN PLACE: Fill tank until material overflows tank opening; Plug or cap all openings; Disconnect and cap or remove vent line; Solid inert material used - specify:

- REMOVAL: Create vent hole, Label tank, Dispose of tank in approved manner. Final tank destination: SAFEWAY TANK DISPOSAL COLFAX, NC

VIII. Certification (Read and Sign)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative: STEPHEN J. GOSSELIN/LAW ENGINEERING ON BEHALF OF MONTGOMERY WARD & CO., INC.

Signature

Date Signed: 4/30/93