



North Carolina Department of Environment and Natural Resources

Michael F. Easley, Governor
William G. Ross Jr., Secretary

Division of Waste Management
Underground Storage Tank Section

Dexter R. Matthews, Director

June 9, 2008

Piedmont Natural Gas Company, Inc.
Attn: Mr. Michael DePalma
P.O. Box 33068
Charlotte, NC 28233

Re: Notice of No Further Action
15A NCAC 2L .0407(d)
Risk-based Assessment and Corrective Action
for Petroleum Underground Storage Tanks

PNG Operations Center
2623 Uwharrie Road
High Point, Guilford County
Risk Classification: Low
Ranking: LOR

Dear Mr. DePalma:

The Underground Storage Tank (UST) Closure Report received by the Underground Storage Tank (UST) Section, Winston-Salem Regional Office on May 1, 2008 has been reviewed. The review indicates that after tank closure soil contamination does not exceed the action level of 10 parts per million TPH-GRO.

The UST Section determines that no further action is warranted for this incident. This determination shall apply unless the UST Section later finds that the discharge or release poses an unacceptable risk or a potentially unacceptable risk to human health or the environment. Pursuant to Title 15A NCAC 2L .0407(a) you have a continuing obligation to notify the Department of any changes that might affect the risk or land use classifications that have been assigned.

This No Further Action determination applies only to the subject incident; for any other incidents at the subject site, the responsible party must continue to address contamination as required.

If you have any questions regarding this notice, please contact Sharon K. Cihak at the Guilford County Dept. of Public Health, 1203 Maple Street, Greensboro, NC 27405 and/or at (336) 641-3541.

Sincerely,

Cindy H. Rintoul, L.G.
Regional Supervisor
Winston-Salem Regional Office

cc: Guilford County Health Department

UST Regional Offices

Asheville (ARO) – 2090 US Highway 70, Swannanoa, NC 28778 **(828) 296-4500**

Fayetteville (FAY) – 225 Green Street, Suite 714, Systel Building, Fayetteville, NC 28301 **(910) 433-3300**

Mooreville (MOR) – 610 East Center Avenue, Suite 301, Mooreville, NC 28115 **(704) 663-1699**

Raleigh (RRO) – 1628 Mail Service Center, Raleigh, NC 27699 **(919) 791-4200**

Washington (WAS) – 943 Washington Square Mall, Washington, NC 27889 **(252) 946-6481**

Wilmington (WIL) – 127 Cardinal Drive Extension, Wilmington, NC 28405 **(910) 796-7215**

Winston-Salem (WS) – 585 Waughtown Street, Winston-Salem, NC 27107 **(336) 771-5000**

Guilford County Environmental Health, 1203 Maple Street, Greensboro, NC 27405, **(336) 641-3771**

FTP: NFA closure-IAA NOR0606.dot

PNG Operations Center

- USGS MAP
- BASE MAP *needs to be to scale*
- ORIENTATION OF UST
- 26.5' LENGTH OF UST
- 8' DIAMETER OF UST
- VOLUME OF UST *8,000 gal.*
- MATERIAL STORED *gasoline*
- SAMPLE LOCATIONS
- DEPTH OF SAMPLE
- 13' 15' SIDE OR FLOOR SAMPLE
- 4' to top DEPTH OF TANK BURIAL
- HOW SAMPLE WAS COLLECTED
- SAMPLES PRESERVED AND TRANSPORTED
- NA *gloved hands* TOOLS DECONTAMINATED
- TIME/DATE SAMPLE COLLECTED
- TIME/DATE LAB RECEIVED
- LAB RESULTS
- ANALYSIS METHOD *5030*
- C.O.C.
- REFERENCE TO SAMPLING POINT ON MAP
- CORRECT # OF SAMPLES
- WITHIN 14 DAYS HOLDING TIME FOR SAMPLES
- TANK AND CONTENTS DESTINATION
- NA DISPOSITION OF SOIL
- REMOVAL DATE *3-13-08*
- COMPLETE GW/UST-2 FORM
- SIGNED + SEALED

3-27-08 Rec'd. UST-3, notice of intent: UST permanent closure
BUT, they had filled the UST on 3-13-08

5-1-08 Rec'd. UST closure report

- tank used by PNG since 1991 to fuel company vehicles.
- highest soil sample result 8.5 ppm (5030).