UNDERGROUND STORAGE TANKS (UST's)

Foindexter Lumber

(CHECK APPROPRIATE RESPONSE)

REGULATED ✓ NONREGULATED _____

RELEASE CONFIRMED ?	YES _____	NO X
CLEAN-UP INITIATED ?	YES _____	NO _____
TANKS REMOVED ?	YES X	NO _____
RELEASE UNDER CONTROL?	YES _____	NO _____
CLEAN-UP COMPLETED?	YES _____	NO _____

295
1/10/92

ITE Poindexter lumber

REVIEW DATES 3/25/96

X USGS MAP
√ BASE MAP
√ ORIENTATION OF UST
√ DIMENSIONS OF UST 4' x 10' 6" / 5' 4" x 1' 1"
√ VOLUME OF UST 4(1,000) 1(6000) 1(8000)
√ MATERIAL STORED Gas / Diesel
√ APPROPRIATE SAMPLE LOCATIONS
√ DEPTH OF SAMPLE 2' BUST
√ SIDE OR FLOOR SAMPLE
√ DEPTH OF TANK BURIAL 2'
√ HOW SAMPLE WAS COLLECTED backhoe bucket
√ ? SAMPLES PRESERVED & TRANSPORTED
√ TOOLS DECONTAMINATED
√ TIME/DATE SAMPLE COLLECTED
√ TIME/DATE LAB RECEIVED
√ LAB RESULTS
√ CHAIN-OF-CUSTODY
√ ANALYSIS METHOD 5030 / 3550
√ REFERENCE TO SAMPLING POINT ON MAP
√ CORRECT # OF TANK SAMPLES
— PUMP/LINE SAMPLES Didn't require
√ WITHIN 14 DAY HOLDING TIME (or appropriate time)
√ TANK DESTINATION
NA DISPOSITION OF SOIL
√ CLOSURE DATE June 26-28, 97
√ COMPLETE GW/UST-2 FORM
NA CERTIFIED LABORATORY USED
SSE ACCEPTABLE
NA SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)