

Site Investigation Report For Permanent Closure of U.S.T.

FOR TANKS IN NC

Return Completed Form To:
The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (BLUE) FOR REGIONAL OFFICE ADDRESS].

Sate Use Only
I.D. Number _____
Date Received **RECEIVED**

INSTRUCTIONS

Please complete and return within (30) days following completion of site investigation.

AUG 22 1991

I. Ownership of Tank(s)

Poindexter Lumber Company
Owner Name (Corporation, Individual, Public Agency, or Other Entry)
202 Belews St.
Street Address
Forsyth
County
Winston-Salem, NC 27101-4003
City State Zip Code
(919) 722-5115 Telephone Number
Area Code Telephone Number

II. Location of Tank(s)

Poindexter Lumber Company Winston-Salem
Facility Name or Company Regional Office
Facility ID # (if available)
1805 Stratford Road
Street Address or State Road
Forsyth Winston-Salem, NC
County City Zip Code
(919) 765-1650 Telephone Number
Area Code Telephone Number

III. Contact Person

Name Job Title Telephone Number
Julianne M. Braun Staff Hydrologist; Engineering Tectonics, P.A. (919) 727-0063
Closure Contractor **M&M Pump & Tank Service; 6260 Jennings Road; Lewisville, NC 27023**
(Name) (Address)
Lab **Shealy Environmental Services; 400 Graymont Ave.; Columbia, SC 29205**
(Name) (Address)

IV. U.S.T. Information

V. Excavation Condition

VI. Additional Information Required

Tank No.	Size in Gallons	Tank Dimensions	Last Contents	Water In Excavation		Free Product		Notable Odor or Visible Soil Contamination	
				Yes	No	Yes	No	Yes	No
1	1,000	4'x10'6"	Gasoline		X		X		X
2	1,000	4'x10'6"	Diesel Fuel		X		X		X
3	1,000	4'x10'6"	Gasoline		X		X		X
4	1,000	4'x10'6"	Diesel Fuel		X		X		X
5	6,000	4'x16'	Diesel Fuel		X		X		X
6	8,000	5'4"x16'	Gasoline		X		X		X

See reverse side of blue copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

7 4,000 4'8"x24' Diesel Fuel Check the activities completed.

- Contact local fire marshal
- Notify DEM Regional Office before abandonment.
- Drain & flush piping into tank.
- Remove all product and residuals from tank
- Excavate down to tank.
- Clean and inspect tank.
- Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures.
- Cap or plug all lines except the vent and fill lines.
- Purge tank of all product & flammable vapors.
- Cut one or more large holes in the tanks.
- Backfill the area.

Date Tank Permanently closed: June 26-28, 1991

- ABANDONMENT IN PLACE**
- Fill tank until material overflows tank opening;
 - Plug or cap all openings;
 - Disconnect and cap or remove vent line
 - Solid inert material used - please specify: _____

- REMOVAL**
- Create vent hole
 - Label tank
 - Dispose of tank in approved manner
- Final tank destination: Safeway Tank Disposal

United Metal Recyclers

VIII. Certification (Read and Sign)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative
JULIANNE M. BRAUN STAFF HYDROLOGIST ENGINEERING TECTONICS

Signature
Julianne M. Braun

Date Signed
8-21-91