



State of North Carolina
Department of Environment, Health, and Natural Resources
Winston-Salem Regional Office

James G. Martin, Governor
William W. Cobey, Jr., Secretary

Margaret Plemmons Foster
Regional Manager

DIVISION OF ENVIRONMENTAL MANAGEMENT
GROUNDWATER SECTION

July 10, 1990

Mr. Tracy Saunders
Piedmont Electric Motor Repair
468 N. Fayetteville Street
Asheboro, NC 27203

Subject: Underground Storage Tank Closure, 468 N. Fayetteville
Street, Asheboro, Randolph County

Dear Mr. Saunders:

We received the soil sample results for the underground storage tank closure at the subject location on June 20, 1990. As the implementing agency for the Federal Underground Storage Tank Program for the State of North Carolina, we have determined that the soil is not contaminated by petroleum products. Therefore, UST system may be abandoned in place in accordance with 40 CFR 280.71 and 280.72. However, this does not absolve you of any responsibility for contamination that may not have been detected during the site assessment.

If you have any questions, please contact me at the letterhead address or telephone number.

Sincerely,

A handwritten signature in cursive script that reads "Andrew M. Raring".

Andrew M. Raring
Hydrogeological Regional
Supervisor

AMR/ahl

cc: WSRO
Central Files