



PIEDMONT ENVIRONMENTAL SERVICES, INC.

P.O. Box 88118631  
Greensboro, NC 27419  
(919) 668-4821

RECEIVED  
N.C. Dept. NRCD

MAY 22 1991

Winston-Salem  
Regional Office

May 3, 1991

Tom Salley  
NCDEHNR  
8025 North Point Blvd. Suite 100  
Winston-Salem, NC 27106

Re: Perkins Restaurant  
2127 Chapel Hill Road  
Burlington, NC  
Alamance County

Dear Mr. Salley;


On May 2, 1991 we removed one 6000 gallon #2 heating oil tank from the above location. Perkins Restaurant is currently under construction at this site. The tank was found by the grading contractor will bringing the parking area to grade.

The tank measured 16 feet by 8 feet. The original depth the tank was buried can not be determined due to the grading work. Two soil samples were taken from the floor of the pit after the tank was removed. The samples were taken two feet under the tank as indicated on the site map attached. The samples were collected from the bucket of our backhoe and stored in an ice cooler until delivered to the lab that afternoon.

The soils under the tank were screened using our hnu meter. The hnu meter did not pick up any signs of contamination in the tank pit area. The soil sample report is attached.

If further information is needed please contact me.

Sincerely,



Thad Chesson

cc: Kenneth M. Smith, Owner  
Carl Sykes, Burlington Fire Department  
Marlin Evans, Attorney



**GUILFORD LABORATORIES, INC.**  
P.O. Box 9735/Plaza Station/Greensboro, N.C. 27408

May 17, 1991

REPORT OF ANALYSIS

JOB #: PES10502  
CUSTOMER: Piedmont Environmental                      ATTN: Thad Chesson  
P.O.#: Perkins Restaurant  
SAMPLE: # 2348 6000 GAL #2 HEATING OIL NORTH  
          # 2349 6000 GAL #2 HEATING OIL SOUTH

<u>RESULTS</u>	<u>2348</u>	<u>2349</u>
Total Petroleum Hydrocarbons (ppm) as Gasoline by EPA Method 5030	<10	<10
Total Petroleum Hydrocarbons (ppm) by EPA Method 3550	<10	<10

Guilford Laboratories, Inc.

  
J. A. Rayburn



\* = sample locations

to I-85 →



Maple Ave.

Perkins Restaurant  
2127 Chapel Hill Rd  
(currently under construction)

parking lot

curb ↘

6000 gallon  
#2 heating  
oil

curb ↘

← 12' →

parking lot

75'

Entrance

curb

entrance

Chapel Hill Rd.

