

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENT AND NATURAL RESOURCES
WINSTON-SALEM REGIONAL OFFICE

6



DIVISION OF WATER QUALITY
GROUNDWATER SECTION

April 22, 1998

JAMES B. HUNT JR.
GOVERNOR

CERTIFIED MAIL P-536 313 855
RETURN RECEIPT REQUIRED

WAYNE McDEVITT
SECRETARY

Segraves Oil Company, Inc.
Attention: Mrs. Barbara Vannoy
P.O. Box 1474
Jefferson, North Carolina 28640

SUBJECT: NOTICE OF VIOLATION of 15A NCAC 2N

Parkway Drive-In
Rt 2
West Jefferson, Ashe County
Facility ID: 0-023926

Dear Mrs. Vannoy:

The Division of Water Quality (DWQ) has discovered that two 1,000 gallon regulated Underground Storage Tanks (USTs) at the subject facility are not in compliance with Federal (Code of Federal Regulations (CFR) Chapter 40 Subpart 280) and/or State UST Regulations (North Carolina Administrative Code (NCAC) Title 15A Subchapter 2N). According to the North Carolina Petroleum UST Database, Segraves Oil Company, Inc. is identified as the owner of these UST systems. Segraves Oil Company, Inc. indicated these tanks were permanently closed on December 31, 1989, however, no information pertaining to the permanent closure was submitted.

The Federal UST regulations, 40 CFR 280 "Underground Storage Tanks; Technical Requirements", became effective December 22, 1988. The State of North Carolina, Department of Environment and Natural Resources (DENR), was delegated the authority to enforce these Federal regulations until State regulations were adopted. On January 1, 1991, the State of North Carolina incorporated by reference 40 CFR 280 into the North Carolina Administrative Code, 15A NCAC 2N "*Criteria and Standards Applicable to Underground Storage Tanks.*".

Information pertaining to the following violations was obtained by Michael Amsbaugh of the DWQ, Winston-Salem Regional Office.

VIOLATION 1:

Failure to notify the DWQ of compliance with permanent closure requirements within 30 days following closure (tank removal or abandonment) as required by 40 CFR 280.74 incorporated by reference into 15A NCAC 2N .0405.

REQUIRED CORRECTIVE ACTION for Violation 1:

A tank closure report providing evidence of compliance with the requirements established in Federal regulation 40 CFR 280.71 and 280.72 (incorporated by reference into 15A NCAC 2N Sections .0802 and .0803) and the *Groundwater Section Guidelines for the Investigation and Remediation of Soils and Groundwater* must be submitted along with the GW/UST-2 form titled "Site Investigation Report for Permanent Closure or Change in Service." Please immediately, submit the GW/UST-2 form and the tank closure report (GW/UST-12 format is required as of February 1, 1995) to Michael Amsbaugh at the address on the bottom of the letterhead page.


Note: Engineering or geological work must be performed under the direct supervision of a Professional Engineer (P.E.), Licensed Geologist (L.G.), or professionally licensed firm. For information concerning the requirements of engineering or geological work, you may contact the appropriate licensing board.

Unless another deadline has been specified in the applicable corrective actions for the violations identified above, all necessary information to verify compliance must be submitted to Michael Amsbaugh, at the address on the bottom of the letterhead page, **within 45 days after receipt of this Notice.**

As a registered tank owner, Segraves Oil Company, Inc. maintains responsibility to comply with Federal and State regulations for underground storage tanks. Copies of State regulations 15A NCAC 2N are available at this office.

Your cooperation is appreciated. If you believe that the inspection findings are in error, or if you have any questions pertaining to this Notice, please contact Michael Amsbaugh at (336) 771-4608 extension 294.

Sincerely,



Larry D. Coble
Regional Supervisor
Winston-Salem Regional Office

cc: Regional Office Files
Geonetics
Ashe County Health Department
Ashe County Fire Marshal

P-536 313 855

REGISTERED MAIL
POSTAGE AND FEES PAID
BY ADDRESSEE
(See Reverse)

U.S.G.P.O. 153-506

Sent to	
Street and No.	
P.O., State and ZIP Code	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	

Return Receipt showing

Ashe HE 0-623926

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- Addressee's Address
- Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Seagraves Oil Company, Inc.
Attention: Mrs. Barbara Vannoy
P.O. Box 1474
Jefferson, North Carolina 28640

4a. Article Number
P-536-313-855

4b. Service Type

<input type="checkbox"/> Registered	<input checked="" type="checkbox"/> Certified
<input type="checkbox"/> Express Mail	<input type="checkbox"/> Insured
<input checked="" type="checkbox"/> Return Receipt for Merchandise	<input type="checkbox"/> COD

5. Received By: (Print Name)

7. Date of Delivery
4-27-98

8. Addressee's Address (Only if requested and fee is paid)

6. Signature: (Addressee or Agent)

X

Thank you for using Return Receipt Service.

SEGRAVES OIL COMPANY
ASHE CO.

SITE	FACILITY	PIRF	VIOLATIONS	RISK	SOIL	GROUNDWATER	STATUS
Moore's Exxon	0-023930	6146	12/96 2L NOV	High	TPH @ 9,700 ppm	15-in Free Product	Awaiting CAP
Stephens Exxon	0-000453	16457	9/96 2N NORR	High	TPH @ 12,658 ppm	2,153 ppb BTEX	Awaiting CAP
Minnie Miller's	0-000451	Pend	4/98 2N NORR	unk.	TPH @ 8,850 ppm	Not Evaluated	LSA (?) Due 7/98
Jack & Deans	0-000454	13684	12/96 2N NOV	High	TPH @ 1,461 ppm	No Impact	Awaiting CAP
Dollar's Exxon	0-023923	13794	10/96 2N NOR	Low	TPH @ 2,339 ppm	Not evaluated	LSA (?) Due 7/98
Bulk Plant	0-023937	13757	2/98 2N NORR	Int.	TPH @ 236 ppm	Not evaluated	LSA (?) Due 5/98
Lansing Garage	0-023928	6881	4/98 2N NORR	Low?	TPH @ 157 ppm	Not evaluated	LSA (?) Due 7/98
Richard's	0-023999	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	UST Closure Requested
Ashley Insurance	Unregist.	n/a	4/98 2N NOV	unk.	Not Evaluated	Not evaluated	UST Closure Requested
Parkway Drive-In	0-023926	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (12/31/89)
Big Laurel Exxon	0-023925	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (7/18/90)
Park Vista	0-023939	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (12/17/90)
Blackburn Exxon	0-023938	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (12/17/90)
Midway Grocery	0-023929	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (12/31/88)
Town of Jefferson	0-024103	n/a	4/98 2N NOV	unk.	Not Evaluated	Not Evaluated	Closure Records? (7/10/91)
Hoppers Store	0-023921	n/a	n/a	unk.	Not Evaluated	Not Evaluated	Closure Records? (8/31/86)
Mrs. Ed Liddle	0-023936	n/a	n/a	unk.	Not Evaluated	Not Evaluated	Closure Records? (12/30/86)
W.J. Exxon	0-023931	13016	5/12/97 NFA	High			Dirty Closure
Harold Paisley	0-023927	15099	12/18/96 NFA	High			Dirty Closure
Segraves Oil Co.	0-023937	13755	1/13/97 NFA	Low			Dirty Closure
E. Jeff. Exxon	0-023924	n/a	4/25/96 NFA	Low			Clean Closure
Milams Store	0-000452	n/a	12/8/95 NFA	Low			Clean Closure