

FOR TANKS IN NC

Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (PINK) FOR REGIONAL OFFICE ADDRESS].

State Use Only N.C. Dept. of ENR I.D. Number MAR 03 1992 Date Received

INSTRUCTIONS

Complete and return within (30) days following completion of site investigation.

Regional Office

I. Ownership of Tank(s)

II. Location of Tank(s)

Owner Name: Parks Chevrolet-Geo, Inc. 615 High Point Road, Forsyth, Kernersville, NC 27102. City: 919, State: 993-2101, Zip Code: 919, Area Code: 993-2101, Telephone Number: 919-993-2101

Facility Name or Company: Parks Chevrolet-Geo, Inc. Facility ID # (if available): N/A. Street Address or State Road: 615 High Point Road, Forsyth, Kernersville, NC 27102. City: 919, State: 993-2101, Zip Code: 919-993-2101, Area Code: 993-2101, Telephone Number: 919-993-2101

III. Contact Person

Mr. James Berry, Controller, (919) 993-2101. Closure Contractor: Hardin Pump and Compressor, Rt. 16 Box 519 W-S NC, (919) 769-9128. Lab: Research Analytical Lab, 106 Short Street Kernersville, NC, (919) 996-2320.

IV. U.S.T. Information

V. Excavation Condition

VI. Additional Information Required

Table with columns: Tank No., Size in Gallons, Tank Dimensions, Last Contents, Water In Excavation (Yes/No), Free Product (Yes/No), Notable Odor or Visible Soil Contamination (Yes/No). Row 1: 1, 2,000, 64"x12', Gasoline, No, X, No, X.

See reverse side of pink copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

Check the activities completed.

- Checklist items: Contact local fire marshal, Notify DEM Regional Office before abandonment, Drain & flush piping into tank, Remove all product and residuals from tank, Excavate down to tank, Clean and inspect tank, Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures, Cap or plug all lines except the vent and fill lines, Purge tank of all product & flammable vapors, Cut one or more large holes in the tanks, Backfill the area. Date Tank(s) Permanently closed: 2/10/92, Date of Change-In-Service: [blank]

- ABANDONMENT IN PLACE: Fill tank until material overflows tank opening; Plug or cap all openings; Disconnect and cap or remove vent line; Solid inert material used - specify: [blank]

- REMOVAL: Create vent hole, Label tank, Dispose of tank in approved manner. Final tank destination: Safeway Tank Disposal

VIII. Certification (Read and Sign)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative

Jerry W. Covington / J. J. Jenson

Signature

Jerry W. Covington

Date Signed

2/17/92