

FOR TANKS IN NC

Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE MAP ON REVERSE SIDE OF OWNER'S COPY (PINK) FOR REGIONAL OFFICE ADDRESS].

RECEIVED State Use Only N.C. Dept. NRCO I.D. Number Date Received DEC 10 1991

INSTRUCTIONS

Complete and return within (30) days following completion of site investigation.

Winston-Salem Regional Office

I. Ownership of Tank(s)

II. Location of Tank(s)

Alamance Oil Co
Owner Name (Corporation, Individual, Public Agency, or Other Entity)
1525 W. Webb Ave
Street Address
Alamance
County
Durham NC 27219
City State Zip Code
919 226 9371
Area Code Telephone Number

Parham Shell
Facility Name or Company
6-024149
Facility ID # (if available)
627 E Davis St
Street Address or State Road
Alamance Durham 27215
County City Zip Code
919 - none
Area Code Telephone Number

III. Contact Person

Michael R. Johnston MANAGER 919-226-9371
Name Job Title Telephone No. (Area Code)
Closure Contractor Tailored Foam, Inc P.O. Drawer 4156 704-322-0512
(Name) (Address) Telephone No. (Area Code)
Lab Guilford Laborator. 2 P.O. Box 9735 Greensboro do not have
(Name) (Address) Telephone No. (Area Code)

IV. U.S.T. Information

V. Excavation Condition

VI. Additional Information Required

Table with 10 columns: Tank No., Size in Gallons, Tank Dimensions, Last Contents, Water In Excavation (Yes/No), Free Product (Yes/No), Notable Odor or Visible Soil Contamination (Yes/No). Rows 1-4 contain data for tanks 1, 2, 3, and 4.

See reverse side of pink copy (owner's copy) for additional information required by N.C. - DEM in the written report and sketch.

VII. Check List

Check the activities completed.

- Checklist items: Contact local fire marshal, Notify DEM Regional Office before abandonment, Drain & flush piping into tank, Remove all product and residuals from tank, Excavate down to tank, Clean and inspect tank, Remove drop tube, fill pipe, gauge pipe, vapor recovery tank connections, submersible pumps and other tank fixtures, Cap or plug all lines except the vent and fill lines, Purge tank of all product & flammable vapors, Cut one or more large holes in the tanks, Backfill the area. Date Tank(s) Permanently closed: 11/20/91

- Checklist items: ABANDONMENT IN PLACE: Fill tank until material overflows tank opening; Plug or cap all openings; Disconnect and cap or remove vent line; Solid inert material used - specify: Filled with Foam. REMOVAL: Create vent hole, Label tank, Dispose of tank in approved manner, Final tank destination.

VIII. Certification (Read and Sign)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate, and complete.

Print name and official title of owner or owner's authorized representative: Alamance Oil Co - Michael R Johnston MANAGER
Signature: Michael R Johnston
Date Signed: 12/2/91

Alamance Oil Company

1525 WEST WEBB AVENUE - BURLINGTON, N.C. 27217


Permanent Closure of Platform Still - 627 E Davis St, Burlington

- A. NO Contamination
- B. EPA Method 5030
- C. Soil sample Bored - 10' to 12' - same as monitoring well
- D. Fracture


Permit was obtained by Tailored Form - Do not have a copy.




1000
Supplier



Tucker St



Davis St



1525 WEST WEBB AVENUE - BURLINGTON, N.C. 27217

Alamance Oil Company

NITE PHONE 226-9371

DAY PHONE 226-9371

3 miles south of
Dorothy in Burlington
City water tower