

(GW/UST-3)

Notice of Intent: UST Permanent Closure or Change-In-Service

RECEIVED

FOR TANKS IN NC

Return Completed Form To: The appropriate DEM Regional Office according to the county of the facility's location. [SEE REVERSE SIDE OF OWNER'S COPY (PINK) FOR REGIONAL OFFICE ADDRESS].

State Use Only N.C. Dept. NRC I. D. Number Date Received OCT 15 1991

INSTRUCTIONS

Complete and return thirty (30) days prior to closure or change-in-service.

Winston-Salem Regional Office

I. OWNERSHIP OF TANK(S)

Tank Owner Name: Alamance Oil Co
Street Address: 1525 W. Webb Ave
County: Alamance
City: Burlington State: NC Zip Code: 27217
Tele. No. (Area Code): (919) 226-9371

II. LOCATION OF TANK(S)

Facility Name or Company: Parkam Shell
Facility ID #: 0024149
Street Address or State Road: 627 E. Davie St
County: Alamance City: Burlington Zip Code: 27217
Tele. No. (Area Code):

III. CONTACT PERSON

Name: Michael R. Johnston Job Title: MANAGER Telephone Number: (919) 226-9371

IV. TANK REMOVAL, CLOSURE IN PLACE, CHANGE-IN-SERVICE

- 1. Contact Local Fire Marshall.
2. Plan the entire closure event.
3. Conduct Site Soil Assessments.
4. If Removing Tanks or Closing in Place refer to API Publications. 2015 "Cleaning Petroleum Storage Tanks" & 1604 "Removal & Disposal of Used Underground Petroleum Storage Tanks".
5. Provide a sketch locating piping, tanks and soil sampling locations.
6. Fill out form GWUST-2 "Site Investigation Report for Permanent Closure" and return within 30 days following the site investigation.
7. Keep records for 3 years.

V. WORK TO BE PERFORMED BY:

(Contractor) Name: Tailored Form, Inc
Address: P.O. Drawer 4186 State: NC Zip Code: 28603
Contact: Madeline Wright Hickory Phone: 704-322-6512

VI. TANK(S) SCHEDULED FOR CLOSURE OR CHANGE-IN-SERVICE

Table with columns: TANK ID#, TANK CAPACITY, LAST CONTENTS, PROPOSED ACTIVITY (CLOSURE: Removal, Abandonment In Place; CHANGE-IN-SERVICE: New Contents Stored). Rows 1-4 with handwritten entries for gasoline and removal/abandonment.

VII. OWNER OR OWNER'S AUTHORIZED REPRESENTATIVE

Print name and official title: Michael R. Johnston, MANAGER
Signature: Michael Johnston
*Scheduled Removal Date: 11/20/91
Date Submitted: 10/10/91

*If scheduled work date changes, notify your appropriate DEM Regional Office 48 hours prior to originally scheduled date.

Matrix Codes:

- S = Soil
- WM = Waste Water
- DM = Drink. Water
- GM = Ground Water
- 0 = Other

Sampler's Name : Tim Holland
 Sampling Date : 4/30/91
 Sampling Time : 2:15 PM

Sampling Site : Parham Shell
627 E. Davis
Burlington, Vt. 05405
27215

Matrix : S Container : PEH (SR50) Preservation : Analysis

Sample Description	Matrix	Container	Preservation	Analysis
#1 Super Regular	S			
#4 " "	S			
#8 Super Unlead	S			
#5 " "	S			
#3 Reg Unlead	S			
#6 " "	S			

Relinquished by : Tim Holland Date: 4/30/91 Time: 3:50 (p/a)

Received by : _____ Date: ___/___/___ Time: ___:___ (p/a)

Relinquished by : _____ Date: ___/___/___ Time: ___:___ (p/a)

Received by : _____ Date: ___/___/___ Time: ___:___ (p/a)



GUILFORD LABORATORIES, INC.
P.O. Box 9735, Plaza Station/Greensboro, N.C. 27408

May 8, 1991

REPORT OF ANALYSIS

JOB #: JHD10430

CUSTOMER: Jim Holland Service

ATTN: Jim Holland

P.O. #: Parham Shell

SAMPLE: # 2314 #1 SUPER REGULAR
2315 #2 SUPER REGULAR
2316 #3 SUPER UNLEADED
2317 #4 SUPER UNLEADED
2318 #5 REGULAR UNLEADED
2319 #6 REGULAR UNLEADED

<u>RESULTS</u>	<u>2314</u>	<u>2315</u>	<u>2316</u>	<u>2317</u>	<u>2318</u>	<u>2319</u>
Total Petroleum Hydrocarbon (ppm) as Gasoline by EPA Method 5030	(10)	(10)	(10)	(10)	(10)	(10)

Guilford Laboratories, Inc.


J. A. Rayburn



TAILORED FOAM, INCORPORATED
 MANUFACTURERS AND INSTALLERS OF CORE-FILL-500 FOAM INSULATION
 POST OFFICE DRAWER 4186 • HICKORY, NORTH CAROLINA 28603 • TELEPHONE 704/322-6512

DATE

11/27/91

TO Alamance Oil Company
 1525 West Webb Avenue
 Burlington, NC 27217

PROJECT
 Parham Shell Station

Burlington, NC

1 - 4,000 Gallon Tank

3 - 3,000 Gallon Tanks

MESSAGE

Perma Fill Foam installed in tanks above.

All accessible inlets filled with concrete upon completion of work.

Work performed by John Perry, certified applicator.

SIGNED

E. J. Temple, Jr., President

DATE

REPLY
 TO

SIGNED