N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

UNDERGROUND STORAGE TANK(S)

SITE NAME: Pantry # 208

REGULATED ✓ NONREGULATED ____

	YES		NO
RELEASE CONFIRMED:			✓
CLEAN-UP INITIATED:		NA	
TANK(S) REMOVED:	✓		
RELEASE UNDER CONTROL:		NA	
CLEAN-UP COMPLETED:		NA	

TECHNICIAN: Thomas Moore

DATE: 10 / 9 / 95

COMMENTS: waiting for line sample

SITE Pontiy #208 DATE 10/9/95

- ✓ USGS MAP
- ✓ BASE MAP
- ✓ ORIENTATION OF UST
- ✓ DIMENSIONS OF UST 10'6" x 31'0"
- ✓ VOLUME OF UST (2) 10,000 gallon
- ✓ MATERIAL STORED Gasoline
- ✓ APPROPRIATE SAMPLE LOCATIONS
- ✓ X DEPTH OF SAMPLE
- ✓ SIDE OR FLOOR SAMPLE
- X DEPTH OF TANK BURIAL
- ✓ HOW SAMPLE WAS COLLECTED
- ✓ SAMPLES PRESERVED & TRANSPORTED
- ✓ TOOLS DECONTAMINATED
- ✓ TIME/DATE SAMPLE COLLECTED
- ✓ TIME/DATE LAB RECEIVED
- ✓ LAB RESULTS
- ✓ CHAIN-OF-CUSTODY
- ✓ ANALYSIS METHOD 5036
- ✓ REFERENCE TO SAMPLING POINT ON MAP
- ✓ CORRECT # OF TANK SAMPLES
- ✓ X PUMP/LINE SAMPLES
- ✓ WITHIN 14 DAY HOLDING TIME (or appropriate time)
- ✓ TANK DESTINATION
- NA DISPOSITION OF SOIL
- ✓ CLOSURE DATE
- ✓ X COMPLETE GW/UST-2 FORM
- ✓ CERTIFIED LABORATORY USED
- NA SSE ACCEPTABLE
- ✓ SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)