



State of North Carolina
 Department of Natural Resources and Community Development
 Winston-Salem Regional Office

James G. Martin, Governor

William W. Cobey, Jr., Secretary

DIVISION OF ENVIRONMENTAL MANAGEMENT
 GROUNDWATER SECTION

April 4, 1990

College of Home H. Develop
Kay Owen Hancock Esq.
4900 Sugarloaf Rd.
Kennettville, DC 27284

Dear Sir

This letter is to acknowledge your Notification of Tank Closure as received April 2, 1990.

The results of the required assessment (40 CFR, Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 40 CFR 280.71. Any violations will be submitted to EPA with a request for enforcement. Enclosed is an attachment that is to be used for the information required for closure assessment.

You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

Andrew M. Raring

Andrew M. Raring
 Hydrogeological Regional
 Supervisor

AMR/ahl
 Enclosure
 cc: WSRO

Bauchamp, Inc