N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

UNDERGROUND STORAGE TANK(S)

SITE NAME: Norfolk & Western - Auto Car Ramp

REGULATED ✓ NONREGULATED ~~✓~~

	YES		NO
RELEASE CONFIRMED:	~~✓~~		✓
CLEAN-UP INITIATED:		NA	
TANK(S) REMOVED:	✓		
RELEASE UNDER CONTROL:		NA	
CLEAN-UP COMPLETED:		NA	

TECHNICIAN: Rentown Thomas Moore

DATE: 8/3/96 10/10/95

COMMENTS:

SITE Norwalk & Western - Auto Car Ramp DATE 10/10/95

✓ USGS MAP
✓ BASE MAP
✓ ORIENTATION OF UST
✓ DIMENSIONS OF UST 4' X 10' 7"
✓ VOLUME OF UST ~~500~~ (1000)
✓ MATERIAL STORED 5030 ~~/ 3550~~ Gasoline
✓ APPROPRIATE SAMPLE LOCATIONS
X DEPTH OF SAMPLE
✓ SIDE OR FLOOR SAMPLE
✓ DEPTH OF TANK BURIAL
✓ HOW SAMPLE WAS COLLECTED Grab / hand auger
✓ SAMPLES PRESERVED & TRANSPORTED
✓ TOOLS DECONTAMINATED
✓ TIME/DATE SAMPLE COLLECTED
✓ TIME/DATE LAB RECEIVED
✓ LAB RESULTS
✓ CHAIN-OF-CUSTODY
✓ ANALYSIS METHOD 5030
✓ REFERENCE TO SAMPLING POINT ON MAP
✓ CORRECT # OF TANK SAMPLES
NA PUMP/LINE SAMPLES Dispenser or ~~Pump~~ TANK
✓ WITHIN 14 DAY HOLDING TIME (or appropriate time)
TANK DESTINATION
NA DISPOSITION OF SOIL
✓ CLOSURE DATE 5/25/94
✓ COMPLETE GW/UST-2 FORM
✓ CERTIFIED LABORATORY USED
NA SSE ACCEPTABLE
✓ SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)