SITE N.C. Forest Resources

REVIEW DATES _____

- ✓ USGS MAP
- ✓ BASE MAP
- ✓ ORIENTATION OF UST
- ✓ DIMENSIONS OF UST 3.75'x12' / 5.5'x18' / 4.0 / 10'
- ✓ VOLUME OF UST 2(1,000) 1(3,000) (fuel oil #2)
- ✓ MATERIAL STORED diesel / gasoline / fuel oil
- ✓ APPROPRIATE SAMPLE LOCATIONS
- ✓ DEPTH OF SAMPLE 2FT BUST
- ✓ SIDE OR FLOOR SAMPLE
- ✓ DEPTH OF TANK BURIAL 2-3'
- ✓ HOW SAMPLE WAS COLLECTED Stainless steel scoop
- ✓ SAMPLES PRESERVED & TRANSPORTED
- ✓ TOOLS DECONTAMINATED
- ✓ TIME/DATE SAMPLE COLLECTED
- ✓ TIME/DATE LAB RECEIVED
- ✓ LAB RESULTS
- ✓ CHAIN-OF-CUSTODY
- ✓ ANALYSIS METHOD 5030/3550
- ✓ REFERENCE TO SAMPLING POINT ON MAP
- ✓ CORRECT # OF TANK SAMPLES
- ✗ PUMP/LINE SAMPLES need another sample under 2nd dispenser
- ✓ WITHIN 14 DAY HOLDING TIME (or appropriate time)
- ✓ TANK DESTINATION
- NA DISPOSITION OF SOIL
- ✓ CLOSURE DATE 8/30/93
- ✓ COMPLETE GW/UST-2 FORM
- CERTIFIED LABORATORY USED
- NA SSE ACCEPTABLE
- ✓ SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)

TANK # 2 Only needed 5030

✓ TANK # 1 5030/3550

✱ TANK # 3 needed to run or 3550

Is it kaos.

GW/UST-2 & GW/UST-3 are not the same.

{3 TANKS UST2 ? 4 Tanks UST3 ?}

HOLD NOV

UST "24-Hour Notice" Information Sheet

Name Vick Owen NC Forest service Phone # 704-956-2111

Date _____ Time _____ By ZDS

Tank Owner and Address NC Forest Service

Rt 16 Box 212 Lex 27292

Location Lexington, Hargrave rd

Directions _____

Nature of Release:

Product #2 Size of Tank 550

Amount Lost _____ Age of Tank _____

Free Product Yes/No unknown

How was release discovered? water in tank

290 gal fuel in tank now 390.

Was it reported within 24 hours of discovery? (Yes)/No

Tank removal to take place (if applicable) _____
date

Comments: