SITE NC DOT - Reidsville REVIEW DATES 3/8/96

— USGS MAP
√ BASE MAP
√ ORIENTATION OF UST
√ DIMENSIONS OF UST 37' x 14'
√ VOLUME OF UST 3(10,000)
√ MATERIAL STORED Diesel / Gasoline
√ APPROPRIATE SAMPLE LOCATIONS
X DEPTH OF SAMPLE
√ SIDE OR ~~FLOOR SAMPLE~~
— ~~Ø~~ DEPTH OF TANK BURIAL
— / HOW SAMPLE WAS COLLECTED
— SAMPLES PRESERVED & TRANSPORTED
— TOOLS DECONTAMINATED
√ TIME/DATE SAMPLE COLLECTED
√ TIME/DATE LAB RECEIVED
√ LAB RESULTS
√ CHAIN-OF-CUSTODY
√ ANALYSIS METHOD 5030/3550
√ REFERENCE TO SAMPLING POINT ON MAP
√ CORRECT # OF TANK SAMPLES 91 Guidelines for tank > 20' 3 take 3 soil sample below the tanks - 1 sample under each end & 1 in middle
X PUMP/LINE SAMPLES Don't know where dispenser located
√ WITHIN 14 DAY HOLDING TIME (or appropriate time)
√ TANK DESTINATION
— DISPOSITION OF SOIL
√ CLOSURE DATE 10/29/92
√ COMPLETE GW/UST-2 FORM TNK Dimensions
NA CERTIFIED LABORATORY USED
SSE ACCEPTABLE
NA SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)