

State of North Carolina
Department of Environment,
Health and Natural Resources
Regional Health Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Leesha L. Fuller, Regional Manager



December 2, 1994

CERTIFIED MAIL NUMBER: Z-308 706 311
RETURN RECEIPT REQUESTED

Sean Boyles
Department of Transportation
P. O. Box 25201
Raleigh 27611-5201

**SUBJECT: Underground Storage Tank (UST) Closure Assessment at NC DOT-Corriher,
Clemmons, Forsyth County**

Dear Mr. Boyles:

The Groundwater Section of the Winston-Salem Regional Office is now reviewing the UST closure assessment for the subject location. In order to determine whether or not the closure was performed in accordance with State and Federal regulations, the Groundwater Section must be provided with the following information within *30 days from receipt of this letter*:

- a completed GW/UST-2 "Site Investigation Report For Permanent Closure or Change-in-Service of U.S.T." Enclosed you will find a blank copy or the original on which incomplete areas have been highlighted;
- a sample protocol: how the samples were collected (i.e. with shovel, auger, backhoe, etc.) and how the samples were preserved and transported;
- a description of the decontamination procedures used during sample collection;
- the depth of tank burial(s) - the depth should be measured from land surface to the top of tank(s); and,
- sample under associated dispensers and one sample for every 20 feet of piping (identify length of piping if less than twenty feet).

All soil sample analyses must be accompanied by a chain-of-custody and the sampling protocol. *Please note that all subsurface investigative work is now required to be supervised by a Licensed Geologist or Professional Engineer, with all reports signed and sealed by that*

professional. Your cooperation is appreciated. Please refer to the file name, NC DOT-Corriher, on the cover letter of your reply. This will help us speed up the review. If you have any questions please contact me at the letterhead address and/or telephone number.

Sincerely,

Shuying Wang

Shuying Wang
Hydrogeological Technician

cc: WSRO Files

2 308 706 311



Receipt for Certified Mail

No Insurance Coverage Provided

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, and 4a & b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1. Addressee's Address
- 2. Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Sean Boyle
DOT
PO Box 25201
Raleigh NC 27611-5201

4a. Article Number

308 706 311

4b. Service Type

- Registered
- Certified
- Express Mail
- Insured
- COD
- Return Receipt for Merchandise

7. Date of Delivery

12/6/94

5. Signature (Addressee)

J. Boyle

6. Signature (Agent)

J. Boyle

8. Addressee's Address (Only if requested and fee is paid)

Thank you for using Return Receipt Service.