N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

# UNDERGROUND STORAGE TANK(S)

SITE NAME: Baptist Hospital

REGULATED ✓ NONREGULATED ____

| | YES | NO |
|---|---|---|
| RELEASE CONFIRMED: | | ✓ |
| CLEAN-UP INITIATED: | | |
| TANK(S) REMOVED: | ✓ | |
| RELEASE UNDER CONTROL: | | |
| CLEAN-UP COMPLETED: | | |

TECHNICIAN: Sabra Elder / TKM

DATE: 2 / 24 / 97

COMMENTS: Clean Closure

SITE Baptist Hospital REVIEW DATES 2/21/97

REGUST NONREG NONUST (circle) REVIEWER Tkm

make sure say 1 550 gallon UST

- ✓ USGS MAP
- ✓ BASE MAP
- ✓ ORIENTATION OF UST
- ✓ DIMENSIONS OF UST 5.6' x 46"
- ✓ VOLUME OF UST 550
- ✓ MATERIAL STORED Diesel
- NA POTENTIAL RECEPTOR INFORMATION (closures 2/1/95 or after)
- ✓ APPROPRIATE SAMPLE LOCATIONS
- ✓ DEPTH OF SAMPLE 7'
- ✓ SIDE OR ~~FLOOR SAMPLE~~
- OK (X) DEPTH OF TANK BURIAL
- ✓ HOW SAMPLE WAS COLLECTED GRAB
- ✓ SAMPLES PRESERVED & TRANSPORTED
- ✓ TIME/DATE SAMPLE COLLECTED
- ✓ TIME/DATE LAB RECEIVED
- ✓ LAB RESULTS
- ✓ CHAIN-OF-CUSTODY
- ✓ ANALYSIS METHOD 5030 / 3550
- ✓ REFERENCE TO SAMPLING POINT ON MAP
- ✓ CORRECT # OF TANK SAMPLES
- NA (X) PUMP SAMPLES
- (X) LINE SAMPLES
- ✓ WITHIN 14 DAY HOLDING TIME (or appropriate time)
- ✓ TANK DESTINATION Interway Tank disposal
- ✓ SLUDGE DESTINATION
- NA DISPOSITION OF SOIL
- ✓ CLOSURE DATE June 5, 1994
- ✓ COMPLETE GW/UST-2 FORM (1/1/91 and after)
- ✓ CERTIFIED LABORATORY USED (closures 8/1/93 and after)
- NA SSE ACCEPTABLE
- ✓ SEALED BY LG or (PE) (closures 1/1/94 and after)
- NA UST-12 FORMAT (closures 2/1/95 and after)

NAME/# OF SEALER John Riley / PE

CONSULTING COMPANY Engineering Tectonics, P.A