N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

UNDERGROUND STORAGE TANK(S)

SITE NAME: Baptist Hospital - Ambulatory Care Unit

REGULATED ✓ NONREGULATED ____

	YES	NO
RELEASE CONFIRMED:		✓
CLEAN-UP INITIATED:		
TANK(S) REMOVED:	✓	
RELEASE UNDER CONTROL:		
CLEAN-UP COMPLETED:		

TECHNICIAN: TKM

DATE: 2/21/97

COMMENTS: Clean closure

SITE Baptist Hospital - Ambulatory Care Unit REVIEW DATES 2/21/97

REGUST NONREG NONUST (circle) REVIEWER TKM

✓ USGS MAP
✓ BASE MAP
✓ ORIENTATION OF UST
✓ DIMENSIONS OF UST 74" x 48"
✓ VOLUME OF UST 1000
✓ MATERIAL STORED Diesel
✓ POTENTIAL RECEPTOR INFORMATION (closures 2/1/95 or after)
APPROPRIATE SAMPLE LOCATIONS
✓ DEPTH OF SAMPLE 7'
✓ SIDE OR FLOOR SAMPLE
X DEPTH OF TANK BURIAL line
✓ HOW SAMPLE WAS COLLECTED GRAB
✓ SAMPLES PRESERVED & TRANSPORTED
✓ TIME/DATE SAMPLE COLLECTED
✓ TIME/DATE LAB RECEIVED
✓ LAB RESULTS
✓ CHAIN-OF-CUSTODY
✓ ANALYSIS METHOD 5030 / 3550
✓ REFERENCE TO SAMPLING POINT ON MAP
✓ CORRECT # OF TANK SAMPLES
NA PUMP SAMPLES
LINE SAMPLES Lines into building / ≈15' VA Consultants will fax info
✓ WITHIN 14 DAY HOLDING TIME (or appropriate time)
✓ TANK DESTINATION ~~Secure tank disposal~~ Crumpler Farm
✓ SLUDGE DESTINATION
DISPOSITION OF SOIL
✓ CLOSURE DATE August 12, 94
✓ COMPLETE GW/UST-2 FORM (1/1/91 and after)
✓ CERTIFIED LABORATORY USED (closures 8/1/93 and after)
SSE ACCEPTABLE
✓ SEALED BY LG or PE (closures 1/1/94 and after)
NA UST-10 FORMAT (closures 2/1/95 and after)

NAME/# OF SEALER John M. Riley / 8233
CONSULTING COMPANY Engineering Tectonics, P.A.