State of North Carolina
Department of Natural Resources and Community Development
Winston-Salem Regional Office

James G. Martin, Governor

William W. Cobey, Jr., Secretary

DIVISION OF ENVIRONMENTAL MANAGEMENT
GROUNDWATER SECTION

June 26, 1990

Jim Raney, Chief
North Eastern
Alamance Fire Dept.
3847 N. NC 49
Burlington, NC 27217

Dear Chief Raney:

This letter is to acknowledge your Notification of Tank Closure as received June 18, 1990.

The results of the required assessment (40 CFR, Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 40 CFR 280.71. Any violations will be submitted to EPA with a request for enforcement. Enclosed is an attachment that is to be used for the information required for closure assessment.

You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

Andrew M. Raring

Andrew M. Raring
Hydrogeological Regional
Supervisor

AMR/ahl
Enclosure
cc: WSRO

8025 North Point Boulevard, Suite 100, Winston-Salem, N.C. 27106-3295 • Telephone 919-761-2351

An Equal Opportunity Affirmative Action Employer