

# memo

## INACTIVE HAZARDOUS SITES BRANCH

To: Stanley Case Goods File (NCD049845266)  
From: Boyles, Sean  
CC:  
Date: June 24, 2016  
Re: Low Priority Status

---

Two supply wells located in close proximity to the Stanley Case Goods Site had previously detected low levels of acetone and other VOCs over three years ago. The supply wells located at 4049 Highway 73 and at 5349 Highway 73 in West End, Moore County NC were resampled on April 12, 2016. Based on the analytical test results, low levels of dichlorodifluoromethane were detected consistent with a possible leak of chlorinated water from a public water line. No other constituents were detected in the samples and therefore no further action is warranted at this time.