

**HAZARDOUS WASTE SECTION - COMPLIANCE BRANCH
FILE TRANSMITTAL & DATA ENTRY FORM**

Your Name: Anthony Foster

Facility ID Number: NCD061263315

Facility Name: NEXEO Solutions, LLC

Document Group: Inspection/Investigation (I)

Document Type: I - Focused Compliance Inspection (FCI)

File Description/Comments: No violations

Date of Document: 6/15/2016

Author(s) of Document: Anthony Foster

Inspector ID #: NC055

Suborganization: Resident Inspector Program

County (if not on report): Mecklenburg

North Carolina Department of Environmental Quality
Division of Waste Management

RESIDENT INSPECTOR REPORT

1) Facility Information

NEXEO Solutions, LLC
3930 Glenwood Drive
Charlotte, NC 28208

EPA ID# NCD 061263315

Permit Status: RCRA
 Air
 Water

2) Facility Contact

James Childs

Arrived: 11:00 am

Departed: 3:30 pm

3) Date of Inspection / Inspector

6/15/16
Anthony Foster

Shift: 1st
 2nd
 3rd
 Wkend

4) Facility Description Changes

None

5) Areas of Concentration

General Physical Container Management Part B Container Dates
Labeling 10-Day Fire Extinguishers

6) Site Deficiencies

None

Docket #: N/A

7) Recommendations/Comments

- 1. Fire extinguishers must be inspected and the inspection date noted on the service tag on a monthly basis. A forklift fire extinguisher had not been inspected in April, 2016 or May, 2016.
- 2. A minimum of two feet of aisle space must be maintained in all waste storage areas. In Bay #1 the top pallet was stacked in such a way that there was not two feet of aisle space between the pallet of waste and the fence which inhibited entry for inspection.

8) Corrections Since Last Inspection

9) Referrals to DAQ/DWQ/OSHA

None



Facility Representative 6-15-16
Date



Anthony Foster - Resident Inspector 6-15-16
Date