

WELL CONSTRUCTION RECORD

253641

North Carolina - Department of Environmental and Natural Resources - Division of Water Quality - Groundwater Section

WELL CONTRACTOR (INDIVIDUAL) NAME (print) DANNY SUMMERS CERTIFICATION # 2579

WELL CONTRACTOR COMPANY NAME GEOLOGIC EXPLORATION, INC. PHONE # (704) 872-7686

STATE WELL CONSTRUCTION PERMIT# _____ ASSOCIATED WQ PERMIT# _____
(if applicable) (if applicable)

1. WELL USE (Check Applicable Box): Residential Municipal/Public Industrial Agricultural
Monitoring Recovery Heat Pump Water Injection Other If Other, list Use _____

2. WELL LOCATION:

Nearest Town: ASHEVILLE County BUNCOMBE

205 SMOKEY PARK HWY
(Street Name, Numbers, Community, Subdivision, Lot No., Zip Code)

Topographic/Land setting
 Ridge Slope Valley Flat
(check appropriate box)
Latitude/longitude of well location _____

3. OWNER:

ASHEVILLE CHEVROLET

Address 205 SMOKEY PARK HWY
(Street or Route No.)

ASHEVILLE NC
City or Town State Zip Code

()
Area Code - Phone Number

(degrees/minutes/seconds)
Latitude/longitude source: GPS Topographic map
(check box)

DEPTH		DRILLING LOG
From	To	Formation Description
0.0	20.0	BROWN/RED SILT
20.0	25.0	BROWN/RED SILT WITH COBBLES
25.0	40.0	BROWN SILT

4. DATE DRILLED 5-6-02

5. TOTAL DEPTH: 40.0 FEET

6. DOES WELL REPLACE EXISTING WELL? YES NO

7. STATIC WATER LEVEL Below Top of Casing: _____ FT.
(Use "+" if Above Top of Casing)

8. TOP OF CASING IS 0.0 FT. Above Land Surface*

*Top of casing terminated at/or below land surface requires a variance in accordance with 15A NCAC 2C .0118.

9. YIELD (gpm): N/A METHOD OF TEST N/A

10. WATER ZONES (depth): N/A

11. DISINFECTION: Type N/A Amount _____

12. CASING: Wall Thickness

From	Depth	To	Diameter	or Weight/Ft.	Material
0.0	0.0	20.0	2 INCH	SCH 40	PVC
From	To	Ft.			
From	To	Ft.			

13. Grout: Depth Material Method

From	0.0	To	16.0	Ft.	Portland Bentonite	Slurry
From	To	Ft.				

14. SCREEN: Depth Diameter Slot Size Material


From	20.0	To	40.0	Ft.	2.0 in.	.010 in.	PVC
From	To	Ft.					

15. SAND/GRAVEL PACK:

From	Depth	To	Size	Material
18.0	0.0	40.0	20-40	FINE SILICA SAND
From	To	Ft.		

16. REMARKS: MW-2A BENTONITE SEAL FROM 16.0 TO 18.0 FEET

I DO HEARBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER



Danny R. Summers
SIGNATURE OF PERSON CONSTRUCTING THE WELL

5-16-02
DATE

Submit the original to the Division of Water Quality, Groundwater Section, 1636 Mail Service Center - Raleigh, NC 27699-1636 Phone No. (919) 733-3221, within 30 days.

GW-1 REV. 07/2001

RECEIVED/DEER
DIVISION OF GROUNDWATER SECTION
02 JUN - 6 AM 10:31

