

Permit No.	Date	Document ID No.
<b>44-06</b>	<b>August 19, 2010</b>	<b>11430</b>

ENVIRONMENTAL • CIVIL • GEOTECHNICAL • WATER • COMPLIANCE

August 19, 2010

09115  
2008 0810 jg.doc

Jim Giauque  
Blue Ridge Paper Products  
175 Main St.  
PO Box 4000  
Canton, North Carolina 28716

Subject: Landfill 6D - South  
Pump Station Start-up

Dear Jim:

In order to receive a Permit to Operate for Area 6D – South, there was one remaining item that required completion; specifically, installation and start-up of the pumps in the pump station. On August 5, 2010, Todd Wilcoxson of our office was at the landfill to observe the installation and start-up of the pumps. The pumps were successfully started that day at pump rates approaching 250 gallons per minute (gpm). During operation of the pumps there were a couple of minor drips noted at some pipe joints. The contractor, Shamrock, repaired the joints on August 19, 2010.

Based on our observations, the pump station is operating as designed. A copy of the detail sheet with the final piping layout and bracing is attached for your files. Please transmit this submittal to Allen Gaither at North Carolina Department of Energy and Natural Resources to receive final approval to operate Area 6D – South.

If you have any questions, please do not hesitate to contact me.

Sincerely,

SEVEE &amp; MAHER ENGINEERS, INC.



Guy H. Cote, Jr., P.E.  
Chief Engineer

Attachment

cc: L. Williams  
W. Von Vitzthume

E:\Brpp\NC\6d-s\Docs\L\2010 0819 jg.doc

