

State of North Carolina
Department of Environment,
Health and Natural Resources
Raleigh Regional Office

James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Boyce A. Hudson, Regional Manager



DIVISION OF LAND RESOURCES
October 14, 1994

Wilson County
PO Box 1728
Wilson, NC 27893
ATTN: Garry C. Mercer, County Manager

Fac/Perm/Co ID #	Date	Doc ID#
ming	7/15/94	DIN 14391

83-01

RE: Letter of Approval
Project Name: Wilson County Landfill
Location: Wilson County
Submitted by: Environmental Investigations
Date Received: 10-7-94
Date Processing Initiated: 10-7-94
New Submittal () Revised (X)

Dear Mr. Mercer:

This office has reviewed the subject Erosion and Sedimentation Control Plan. We find the plan to be acceptable and hereby issue this letter of approval. If any modifications, performance reservations, or recommendations are applicable, a list is enclosed and is incorporated as a part of this letter of approval. If any modifications are not incorporated into the plan and implemented in the field, the site will be in violation of the Sedimentation Pollution Control Act of 1973 (North Carolina General Statute, hereinafter NCGS, 113A-61.1).

The land-disturbing activity described in the plan for this site may be subject to the approval of other Local, State or Federal agencies. This could include the Division of Environmental Management under stormwater or other water quality regulations, the U.S. Army Corps of Engineers under Article 404 jurisdiction, county, city or town agencies under other local ordinances, or other approvals that may be required. The approval issued in this letter cannot supersede any other required permit or approval.

Please be advised that Title 15A, North Carolina Administrative Code, 4B .0018(a) requires that a copy of the approved plan be on file at the job site. Also,

Mr. Mercer
October 14, 1994
page 2


please consider this letter as notice in accordance with the requirements of NCGS 113A-61.1 concerning our right to perform periodic inspections to ensure compliance with the approved plan.

North Carolina's sedimentation pollution control program is performance oriented, requiring protection of the natural resources and adjoining properties. If at any time during this project it is determined that the Erosion and Sedimentation Control Plan is inadequate to meet the requirements of the Sedimentation Pollution Control Act of 1973 (NCGS 113A-51 through 66), this office may require revisions in the plan and its implementation to ensure compliance with the Act.

Please note that this approval is based in part on the accuracy of the information provided concerning financial responsibility. You are requested to file an amended Financial Responsibility Form if any changes become necessary. In addition, it would be helpful if you would notify this office of the proposed starting date for the activity at the subject site.

Your cooperation is appreciated and we look forward to working with you on this project. If there are any questions, please do not hesitate to contact this office at 919/571-4700.

Sincerely,



Wyatt Brown, CPESC
Assistant Regional Engineer
Land Quality Section
Raleigh Regional Office

WB/gb

cc: Gary H. Ahlberg, P.E.

PLAN REVIEW COMMENTS

PROJECT NAME: <i>Wilson Co. Landfill</i>	DATE RECEIVED: <i>10-7-94</i>
LOCATION: <i>Wilson County</i>	REVIEWED BY: <i>Wyatt Brown</i>
New Submittal () Revised (X)	Approved (X) Disapproved ()
Reasons for Disapproval ()	Modifications (X) Performance Reservations ()

1. *The emergency spillways on the sediment basins must be installed in natural ground.*
2. *Check dams are required below the sediment basins until they are installed and stabilized.*
3. *If straw mulch is used, at least 75% of the ground must be covered. The mulch must be anchored immediately after spreading by either a mulch anchoring tool or liquid binder. If asphalt is used, at least 0.10 gallons per square yard must be applied.*

RECOMMENDATIONS AND/OR COMMENTS:

