



NORTH CAROLINA DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES

Dexter R. Matthews, Director

Division of Waste Management

Michael F. Easley, Governor
William G. Ross Jr., Secretary

July 16, 2008

Ms. Brenda McQueen
Currituck County Public Works
P.O. Box 38
Currituck, NC 27929

Re: Comments to the Permit Amendment Application
Currituck County Transfer Station
Maple, Currituck County, North Carolina
Permit No. 27-03T
Doc ID No. 5168

Dear Ms. McQueen:

The Solid Waste Section has reviewed the Operation Plan, updated October 2007, prepared by the Public Works Department, County of Currituck, for the subject facility. The Division has performed an administrative review of your application for a determination of completeness. Your application has been determined to be complete within the context of NCGS 130A-295.8(e). A determination of completeness means that the application includes required components, but does not mean that the components provide all the information that is required for the division to make a decision on the application. This letter is also a technical review of the application. Please address the following comments.

1. Change the title page of Operation Plan to reflect the period of operation 2007 to 2011.
2. Provide the physical location and street address of the facility.
3. Provide site and facility drawings, drawn to scale, showing the property boundaries, waste loading and unloading area, roads, storage areas, sedimentation basins, scales/scale house, gates/fences, concrete foundations/pads, and other physical characteristics of the site.
4. Section II.B. Please explain "C&D debris will be managed through transfer, but not separated at the facility".
5. Provide procedures and frequencies of random inspection to ensure that only permitted waste is delivered.
6. Section II.C. Where is the wastewater and leachate collected in the holding tanks taken or disposed?
7. Please correct the phone number for Chuck Boyette to (252) 948-3913.

8. Please provide contingency plans for equipment breakdown, non-conforming waste delivered to facility, spills, vectors, noise, odors, unusual traffic patterns, long-term power outages affecting the compactor and leachate pump station, etc.
9. Section IV. Specify if the facility will be closed on holidays.

Should you have any questions regarding this letter or wish to discuss the matter further, please contact me at (919) 508-8401 or by email Karim.Pathan@ncmail.net.

Sincerely,

Karim Pathan
Environmental Engineer
Solid Waste Section

Cc: Ed Mussler, DWM
Chuck Boyette, DWM
Dennis Shackelford, DWM
Donna Wilson, DWM
Raleigh Central File – Currituck County (27-03T)