NON RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2593

1. WELL CONTRACTOR:

Rich Lemire
Well Contractor (Individual) Name

SAEDACCO Inc
Well Contractor Company Name

STREET ADDRESS 9088 NORTHFIELD DR

FORTMILL | SC | 29707
City or Town | State | Zip Code

( )- (704) 507-1922
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) MW-33

STATE WELL PERMIT#(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box) Monitoring ☒ Municipal/Public ☐

Industrial/Commercial ☐ Agricultural ☐ Recovery ☐ Injection ☐

Irrigation ☐ Other ☐ (list use)

DATE DRILLED 4-27-2011

TIME COMPLETED 2:00 AM ☐ PM ☒

3. WELL LOCATION:

CITY: TAYLORSVILLE COUNTY ALEXANDER

2500 PAYNES DAIRY RD
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☐ Slope ☒ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 35.83159

LONGITUDE 81.15753

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☒ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. FACILITY- is the name of the business where the well is located.

FACILITY ID #(if applicable) 02-01

NAME OF FACILITY ALEXANDER COUNTY MSWLF

STREET ADDRESS 2500 PAYNES DAIRY RD

TAYLORSVILLE | NC | 28681
City or Town | State | Zip Code

CONTACT PERSON JOSH MITCHELL

MAILING ADDRESS 621 LILEDOWN ROAD

TAYLORSVILLE | NC | 28681
City or Town | State | Zip Code

(818)- 632-9467
Area code - Phone number

5. WELL DETAILS:

a. **TOTAL DEPTH:** 21.38

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☒

c. **WATER LEVEL** Below Top of Casing: 13.37 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 3FEET FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. **YIELD (gpm):** _____ **METHOD OF TEST** _____

f. **DISINFECTION: Type** _____ **Amount** _____

g. **WATER ZONES** (depth):

From 10.37 To >21.38 From _____ To _____
From _____ To _____ From _____ To _____
From _____ To _____ From _____ To _____

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From +3	To 6.38	Ft.	2	SCH40	PVC
From	To	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 3	Ft.	PORTLAND	POURED
From 3	To 5	Ft.	BENTONITE CHIPS	
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From 6.38	To 21.38	Ft.	2 in.	.010 in.	PVC
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From 5	To 21.38	Ft.	#2	SAND
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	10	TAN SILT
10	21	PWR
	21	

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Richy L Lemire — 4-27-2011
SIGNATURE OF CERTIFIED WELL CONTRACTOR — DATE

RICHY L LEMIRE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1b
Rev. 7/05

NON RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2593

1. WELL CONTRACTOR:

Rich Lemire
Well Contractor (Individual) Name

SAEDACCO Inc
Well Contractor Company Name

STREET ADDRESS 9088 NORTHFIELD DR

FORTMILL | SC | 29707
City or Town | State | Zip Code

( )- (704) 507-1922
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable) MW-34

STATE WELL PERMIT#(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box) Monitoring ☒ Municipal/Public ☐

Industrial/Commercial ☐ Agricultural ☐ Recovery ☐ Injection ☐

Irrigation☐ Other ☐ (list use)

DATE DRILLED 4-27-2011

TIME COMPLETED 4:00 AM ☐ PM ☒

3. WELL LOCATION:

CITY: TAYLORSVILLE COUNTY ALEXANDER

2500 PAYNES DAIRY RD
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☐ Slope ☒ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 35.83159

LONGITUDE 81.15753

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☒ GPS ☐ Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. FACILITY- is the name of the business where the well is located.

FACILITY ID #(if applicable) 02-01

NAME OF FACILITY ALEXANDER COUNTY MSWLF

STREET ADDRESS 2500 PAYNES DAIRY RD

TAYLORSVILLE | NC | 28681
City or Town | State | Zip Code

CONTACT PERSON JOSH MITCHELL

MAILING ADDRESS 621 LILEDOWN ROAD

TAYLORSVILLE | NC | 28681
City or Town | State | Zip Code

(828)- 632-9467
Area code - Phone number

5. WELL DETAILS:

a. **TOTAL DEPTH:** 21.19

b. **DOES WELL REPLACE EXISTING WELL?** YES ☐ NO ☒

c. **WATER LEVEL** Below Top of Casing: 8.27 FT.
(Use "+" if Above Top of Casing)

d. **TOP OF CASING IS** 3FEET FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. **YIELD (gpm):** _____ **METHOD OF TEST** _____

f. **DISINFECTION: Type** _____ **Amount** _____

g. **WATER ZONES** (depth):

From 5.27 To >21.19 From ____ To ____
From ____ To ____ From ____ To ____
From ____ To ____ From ____ To ____

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From +3	To 6.19	Ft.	2	SCH40	PVC
From	To	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 3	Ft.	PORTLAND	POURED
From 3	To 5	Ft.	BENTONITE CHIPS	
From	To	Ft.		

8. SCREEN:

	Depth		Diameter		Slot Size		Material
From 6.19	To 21.19	Ft.	2	in.	.010	in.	PVC
From	To	Ft.		in.		in.	
From	To	Ft.		in.		in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From 5	To 21.19	Ft.	#2	SAND
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	10	TAN SILT
10	21	PWR
	21	

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Richy L Lemire — 4-27-2011
SIGNATURE OF CERTIFIED WELL CONTRACTOR — DATE

RICHY L LEMIRE
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1b
Rev. 7/05